

-137

CODED

SIMPSON  
J 22  
10-3-68

MISSISSIPPI  
BOARD OF WATER COMMISSIONERS  
416 North State Street  
Jackson, Mississippi 39201

CODED CODED

WATER WELL DRILLERS LOG

Box 3 1968 Thompson Hill Brown Acadian  
date well completed firm name county well located

LANDOWNER:

Joe Paul Buckley  
Everett Hill Drive  
(mailing address)

description of formations encountered

from to

WELL LOCATION:

sec. 28 T 1 N R 4 E  
S 4 W  
(distance) miles (direction) of (nearest town)

WELL PURPOSE:

Home (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 2"
- (2) total depth (feet) 435
- (3) static water level (feet) 153 below top of ground.
- (4) casing Gal. 118' (material) (depth)  
2" (size) if telescope see back.
- (5) screen 10' 118' (length) (depth to top)  
2" (size) Brass (material)
- (6) pump Gal 3 (HP) (yield gpm)  
(type power)
- (7) electric log YES (yes or no)  
Miss. H. S. (organization running log)
- (8) how well bottom plugged

Blue clay	0	125
Heavy fine sand	125	210
Blue clay	210	228
Fine sand	228	410
	410	435

Joe Paul Buckley  
Everett Hill Drive  
Box 3  
Thompson Hill  
Brown Parish  
Louisiana

NOV 25 1968

MISS. BD. OF WATER COMMISSIONERS

DRILLERS REMARKS:

Miss Buckley  
The well was drilled to meet  
her requirements because  
of the location of the well.

If well telescopes please  
sketch and show depths.

GROUND LEVEL

			X

SECTION \_\_\_\_\_

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen,  
show locations of each on sketch.