

Simpson  
K 19  
9-26-69

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

Sept. 26 1969 Broomfield Light House Simpson  
 date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
(mailing address)			
<u>Broomfield Light House Miss.</u>			
<u>Mendenhall Miss.</u>	<u>clay</u>	<u>0</u>	<u>75</u>
	<u>sand &amp; gravel</u>	<u>10</u>	<u>175</u>

WELL LOCATION:  
 sec. 5 T. 1 N. R. 5 E.  
3 miles S/E of MENDENHALL  
 (distance) (direction) (nearest town)

WELL PURPOSE: home  
 (home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- (1) diameter (inches) 2"
  - (2) total depth (feet) 175'
  - (3) static water level (feet) 75 below above top of ground.
  - (4) casing Plastic, 165'  
 (material) (depth)  
2" if telescope see back.  
 (size)
  - (5) screen 10' 165'  
 (length) (depth to top)  
2" Plastic  
 (size) (material)
  - (6) pump 3/4 6  
 (HP) (yield gpm)  
gas  
 (type power)
  - (7) electric log no  
 (yes or no)  
 (organization running log)
  - (8) how well bottom plugged B/W. 76'

DRILLERS REMARKS:

DEC. 2 1969

MISSISSIPPI  
 BOARD OF  
 WATER COMMISSIONERS

If well telescopes please sketch and show depths.

GROUND LEVEL

X			

SECTION 5

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen, show locations of each on sketch.