

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

COUNTY WELL LOCATED
SUNFLOWER

WELL NUMBER **Q125** CODED

DATE WELL COMPLETED
8-4-88

PERMIT NUMBER

NAME OF DRILLING FIRM
IRRIGATION EQUIPMENT

601/837-2555

INDIANOLA, MS

CODED

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
BAJA INC.

Box 87

Indianola, MS

WELL LOCATION: SEC **13** TOWNSHIP **18** RANGE **4** (N S) (E W)

DISTANCE **1** Miles DIRECTION **EAST** of NEAREST TOWN **Baird**

OTHER LANDMARK

WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc.
Fish pond

PUMP DATA

PUMP TYPE (Circle One): Submersible Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric Tractor, Diesel, Gasoline, Butane, Other (Describe) **25HP**

Pump Capacity (GPM)	No. of Stages	Setting Depth
1200	1	60 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping

WELL DATA

Well Depth 115'	Casing Diameter (In.) 10	Casing Length (Ft.) 75'
Type of Casing PVC	Hole Depth 115'	Depth to Static Water Level 30'

TYPE OF COMPLETION: (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log


SCREEN DATA

Diameter - Inches 10	Length - Feet 40	Slot Size - Inches .050
Screen Type PVC	Depth to Bottom - Feet 40	

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks
#88-236-SLC-03

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Clay	0	25	 OCT 13 1988 Department of Natural Resources Bureau of Land & Water Resources		
Fine SAND	25	55			
COARSE SAND	55	95			
COARSE SAND with GRAVEL	95	115			

IF MORE SPACE IS NEEDED, USE BACK

