State Well Report

Part 1

County: <u>SUNFLOWER</u>

Permit#: <u>GW 400 36</u>

Driller: <u>SIDNEY COOK</u>

Date drilling completed: <u>4/27/05</u>

Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631
(601)961-5210
(601)354-6938 (fax)

| For Office Use Only: | |
|----------------------|---|
| Aquiter: | _ |
| Well #: 5-94 | _ |
| L.S. Elevation: | _ |
| E-Log #: | |

State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.

| Well Owner Information | Well Location |
|---|---|
| Owner Name ERIC SCHUSTER | Latitude: N 33° 20.374' Longitude: W 90° 45.209' |
| Mailing Address: 2232 HWY 1 NORTH | Method of Lat/Long (circle one): Conventional Survey, |
| | USGS quad, Hand-held GPS Survey-grade GPS |
| GREENVILLE MS 38703 City State Zip Code Telephone No. () | NE |
| | |
| We | ell Data |
| Purpose of Well (circle one) Home Industrial Public Supply | Irrigation Fish Culture Other |
| Date well drilling started: 4/27/05 Date w | ell drilling completed: 4/27/05 |
| If flowing, method of flow regulation: Valve Other (| (describe) |
| Static Water Level: feet above or below (circle one) lan | nd surface Date measured: 4/27/05 |
| Method of Measurement (circle one) steel tape electric tape | air line other: |
| Hole depth: <u>120</u> Well depth: <u>120</u> | Well grouted to a depth of feet |
| Type of grout (circle one): Cement Bentonite Mi | x |
| Casing Length: 80 feet Casing diameter: 16 | inches Type of casing:PVC |
| Screen Length: 40 feet Screen diameter: 16 | inches Type of screen:PVC |
| Screen slot size:inches Setting depth: From | 0 feet to <u>120</u> feet |
| Type of completion (circle all applicable): Gravel packed Under Other (describe): | reamed Telescoped Open hole Natural Development |
| Top of lap pipe or reduction in casing: feet If teles | coped or more than one screen, describe on back of page |
| Logs run (circle all applicable): No log pur Electric Gamma Ray | Density Sonic Neutron Other: |
| Name of organization running log(s): | |
| I certify that the well drilled, constructed, and completed in accord | lance with all applicable requirements of the Mississippi |
| Department of Environmental Quality and/or the Mississippi Department | artment of Health regulations and state laws. |
| Sidney Cook #0-289 | |
| Print Name of Water Well Contractor and License No. | Signature of Water Well Contractor |
| | X |

Ground Level

5-94

| Description of Formations Encountered | From | To |
|---------------------------------------|------|-----|
| Topsoil – Heavy Clay | 0 | 16 |
| Sand | 16 | 48 |
| Gravel and Heavy Sand | 48 | 120 |
| | 1 | |
| | - | |
| | | |
| | - | |
| | _ | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | | |
| | - | |
| | | |
| | _ | |
| | - | |
| | | |
| | | |

If more than one screen, show location of each on sketch

Sketch the property layout and include the following: 1) the well location; 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines, or other items that may aid in locating the property and the well; 4) indicate direction.

Landowner Name:

Eric Schuster

Signature of Waker Well Contractor

STATE WELL REPORT

Part 2

1.

County: __SUNFLOWER

Driller: SIDNEY COOK Date completed: 4/27/05

Permit#:

Pump Installer's Completion Report
Mississippi Department of Environmental Quality
Office of Land and Water Resources
P.O. Box 10631
Jackson, MS 39289-0631 (601)961-5210

(601)354-6938 (fax)

| For | For Office Use Only: | | |
|----------|----------------------|---|--|
| Aquiter: | | | |
| Well #: | 5-94 | _ | |

| Well Owner Information Owner Name <u>ERIC SCHUSTER</u> Mailing Address: <u>2232 HWY 1 NORTH</u> | | Well Location |
|--|--|--|
| | | Latitude: N 33° 20.374' Longitude: W 90° 45.209' |
| | | Method of Lat/Long (circle one): Conventional Survey, USGS quad, Hand-held GPS, Survey-grade GPS |
| CDEE | NVILLE MS 3870 | NE 1/4 SE 1/4 Sec 7 Twn 17N Rng 5W |
| City | State Zip C | |
| Telephone No. (|) | 2 1/2 MilesE of BOURBON |
| | Pump Type Circle one | Power Type Circle one |
| Air Lift | Jet Submersible | Diesel Engine Gasoline Engine Natural Gas |
| Bucket | Piston Turbine | Electric Motor Hand Tractor PTO |
| Centrifugal | Rotary Flowing W | ell Windmill Other (specify): |
| Other (specify): | | Horse Power Rating of Motor: 60 HP |
| Date Pump Installed: 4/29/05 | | Setting Depth: 70 feet |
| Rated Pump Capacity | 7: 2500 Gallons Per Minut | Number of Stages: 1 |
| Pump Test Data | | Method of Measuring Water Level Circle one |
| Date Well Tested: | | Air Line Electric Measuring Line Steel Tape |
| Static Water Level (A): 29 Feet Below Land Surface | | |
| Pumping Water Leve | l (B):Feet Below Land Sur | face |
| Prawdown [(B)-(A)]:Feet Below Land Surface | | face For flowing well, measured shut in head:feet |
| Test Pumping Rate: | Gallons Per Mir | ute Well yieldedGPM with a drawdown of |
| Ouration of Pump Te | st (minimum 4 hours): ho | ursfeet afterhours of pumping |
| HEREBY CERTIFY | (that the above statements are true to | the best of my knowledge. |
| Matt Stephe | ens #0-743P | ٨. ١٠ ٨٠ ١ |
| | Installer and License No. (if applicable | INOTA HABITAT |