

33-52-49
90-16-58

MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

Office of Land and Water Resources

COUNTY WELL LOCATED Tallahatchie	
WELL NUMBER p-98	CODED
DATE WELL COMPLETED 3-9-01	

PERMIT NUMBER
NAME OF DRILLING FIRM Irrigation Equipment Inc. Indianola, MS

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER Due West Farms Box 230 Glendora, MS 38928			
WELL LOCATION nw/ne	SEC 10	TOWNSHIP 23N	RANGE 1W E
DISTANCE 4	DIRECTION North	NEAREST TOWN Glendora	
OTHER LANDMARK Swan Lake			
WELL PURPOSE Home, Irrigation, Municipal, Industrial, Fish Pond, etc. Irrigation			

PUMP DATA		
PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe) _____		
POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) _____ H/P 15		
Pump Capacity (GPM) 750	No of Stages 1	Setting Depth 70 FT.
PUMP TEST		
Well yielded _____ GPM with a drawdown of _____ ft. after _____ hours of pumping		

WELL DATA		
Well Depth 115	Casing Diameter (In) 10	Casing Length (Ft) 75
Type of Casing pvc	Hole Depth 115	Depth to Static Water Level 21ft.
TYPE OF COMPLETION (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe) _____		
WELL GROUTED TO A DEPTH OF _____ FEET Type Grout (circle one): Cement, Bentonite, or Mix		

LOG DATA	
TYPE OF LOG RUN (Circle One): Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe) _____	
Name of Organization Running Log	

SCREEN DATA		
Diameter - Inches 10	Length - Feet 40	Slot Size - Inches .050
Screen Type pvc	Depth to Bottom - Feet 115	

GEOLOGIC DATA (Office Use Only)			
Surface Elev	Geologic Unit	Unit Thickness	Depth to Top
Subs SWL	Date	Analysis	Aquifer Test
Driller's Remarks			
Top of Lap Pipe or Reduction in Casing			
FEET		IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE	

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
Clay	0	20			
Fine Sand	20	65			
Med. Sand	65	75			
Med. Sand & Gravel	75	115			

REC'D JUL 31 2001

IF MORE SPACE IS NEEDED, USE BACK

