MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY
Office of Land and Water Resources

P. O. Box 10631
Jackson, MS 39289-0631
WATER WELL DRILLERS LOG

COUNTY WELL LOCATED: TATE	
WELL NUMBER: J-2129	CODED
PERMIT NUMBER	
NAME OF DRILLING FIRM: HITTS WELL CO.	
DATE WELL COMPLETED: 6-26-00	

NAME & MAILING ADDRESS OF LANDOWNER
Myron or Kim Powers
1201 Jason Patrick Rd.
Holly Springs, MS 38635

WELL LOCATION	SEC	TOWNSHIP	RANGE
	11	5 N (S)	5 E (W)

DISTANCE	DIRECTION	NEAREST TOWN
1 Miles	N of	Wyatte

OTHER LANDMARK

WELL PURPOSE (Circle One): Home, Irrigation, Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One): Submersible, Turbine, Jet, Flowing Well, Other (Describe)

POWER TYPE (Circle One): Electric, Tractor, Diesel, Gasoline, Butane, Other (Describe) H/P 3/4

Pump Capacity (GPM)	No. of Stages	Setting Depth
10		180 FT.

PUMP TEST

Well yielded _____ GPM with a drawdown of no test ft. after _____ hours of pumping

WELL DATA

Well Depth	Casing Diameter (In.)	Casing Length (Ft.)
195	4	185

Type of Casing	Hole Depth	Depth to Static Water Level
PVC	195	130

TYPE OF COMPLETION (Circle One or More): Gravel Packed, Underreamed, Telescoped, Natural Development, Open Hole, Other (Describe)

WELL GROUTED TO A DEPTH OF 3 FEET
Type Grout (circle one): Cement, Bentonite, or Mix

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run, Electric, Gamma Ray, Density, Sonic, Neutron, Other (Describe)

Name of Organization Running Log

SCREEN DATA

Diameter - Inches	Length - Feet	Slot Size - Inches
4	10	.013

Screen Type	Depth to Bottom - Feet
PVC Slotted	185

GEOLOGIC DATA (Office Use Only)

Surface Elev	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing FEET

(IF TELESCOPED OR MORE THAN ONE SCREEN USE BACK PAGE)

DEC

AUG 0 4 2000

Dept. of Environmental Quality
Office of Land & Water Resources

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Red + White Clay	0	15
Red Sand	15	100
White Sand + Clay	100	170
White Sand	170	195

FORMATIONS (Continued)	FROM	TO

IF MORE SPACE IS NEEDED USE BACK