

WALTHALL
D 2003
11-4-76

MISSISSIPPI
 BOARD OF WATER COMMISSIONERS
 416 North State Street
 Jackson, Mississippi 39201

WATER WELL DRILLERS LOG

Nov. 4 1976 Reems well Dr. Walthall
 date well completed firm name county well located

LANDOWNER:
Rayney Van Holmes
At 1 Kokomo
 (mailing address)

WELL LOCATION:
 sec. 19 T 3 N R. 12 E
5 miles east of Salem
 (distance) (direction) (nearest town)

WELL PURPOSE: Home
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

(1) diameter (inches) 4"
 (2) total depth (feet) 140
 (3) static water level (feet) 80 below
 top of ground.
 (4) casing plastic, bottom
 (material) (depth)
4" if telescope see back.
 (5) screen 6", 134'
 (length) (depth to top)
4", plastic
 (size) (material)
 (6) pump 3/4 hp, 12
 (HP) (yield gpm)
elect
 (type power)
 (7) electric log no
 (yes or no)
 (organization running log)

(8) how well bottom plugged
wooden plug

DRILLERS REMARKS:
old well rusty

description of formations encountered	from	to
<u>red clay</u>	<u>0</u>	<u>20</u>
<u>red sand</u>	<u>20</u>	<u>42</u>
<u>red chalk</u>	<u>42</u>	<u>55</u>
<u>pinkish pebbly</u>	<u>55</u>	<u>75</u>
<u>red clay</u>	<u>75</u>	<u>108</u>
<u>granite sand</u>	<u>108</u>	<u>140</u>

RECEIVED
 FEB - 4 1977

MISS. Bd. OF WATER COMMISSIONERS

