

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

WALTHALL
E67
I-70

JAN. 1970 F.B. SHERARD WALTHALL
date well completed firm name county well located

LANDOWNER:	description of formations encountered	from	to
FLETCHER S. CRAWFORD	GRAY CLAY	0	8'
TYLERTOWN, MISS. (mailing address)	SAND & GRAVEL	8'	40'
	CLAY MIXED WITH SAND & GRAVEL	40	55'
WELL LOCATION:	HARD GRAY CLAY	55'	85'
sec. 19 T. 2 N. R. 10 E	FINE SANDY CLAY	85'	140'
6 miles W. of Tylertown	GRAVEL	140	160
(distance) (direction) (nearest town)	50% SAND & 50% GRAY CLAY MIXED SATURATED WITH WATER	160	300
WELL PURPOSE: (home, irrigation, municipal, industrial)	HARD BLUE & GREEN SHALE	300	392
WELL COMPLETION DATA:	SOFTER BROWNISH CLAY	392	432
(1) diameter (inches) 2"	VERY HARD		
(2) total depth (feet) 467	GRAVEL & BLACKISH		
(3) static water level (feet) FLOW below top of ground.	PIEDMONT GRAVEL MIXED		
(4) casing Plastic, 467 (material) (depth)	LIGHT BLUE VERY HARD CLAY BASE	432	467
2" (size) if telescope see back.			
(5) screen 10' (length) (depth to top)			
2 1/2" STA. STEEL (size) (material)			
(6) pump FLOWING IS (HP) (yield gpm)			
(type power)			
(7) electric log (yes or no)			
(organization running log)			
(8) how well bottom plugged BN			

FEB 5 - 1970

MISSISSIPPI BOARD OF WATER COMMISSIONERS

DRILLERS REMARKS:

