

WALTHALL  
 G 35  
 1/6/78

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

CODED

WATER WELL DRILLERS LOG

1/6/78 19 Griver Drilling Service Walthall Co.  
 date well completed firm name county well located

LANDOWNER: Tideway

description of formations encountered from to

#1 Pittman Heirs #25-16

(mailing address)

WELL LOCATION:

sec. 25 T. 2 (N) R. 12 (E)  
 990' N + 990' W of SE Cor. W Dexter Ms  
 miles (distance) of (direction) of (nearest town)

WELL PURPOSE:  
 (home, irrigation, municipal, industrial)

WELL COMPLETION DATA:

- (1) diameter (inches) 3"
- (2) total depth (feet) 336'
- (3) static water level (feet) 89 below top of ground.
- (4) casing Steel, 336' (material) (depth)
- 3" (size) if telescope see back.
- (5) screen 42' 294' (length) (depth to top)
- 3" (size) Perforated Pipe (material)
- (6) pump (HP) 70 (yield gpm)
- AC (type power)
- (7) electric log NO (yes or no)

(organization running log)

(8) how well bottom plugged Orange  
 Pee!

|          |       |         |
|----------|-------|---------|
| Chalk    | CODED | 21      |
| Streaked |       | 51 42   |
| Sand     |       | 43 89   |
| Streaked |       | 40 126  |
| Sand     |       | 127 147 |
| Chalk    |       | 148 169 |
| Sand     |       | 169 336 |

DRILLERS REMARKS:

J. Hudson

RECEIVED

JAN 17 1978

MISSISSIPPI BOARD OF WATER COMMISSIONERS

