

**MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL  
QUALITY**

Office of Land and Water Resources

P. O. Box 10631

Jackson, MS 39289-0631

**WATER WELL DRILLERS LOG**

COUNTY WELL LOCATED  
Walworth

WELL NUMBER CODED  
H2129

DATE WELL COMPLETED  
10-25-99

PERMIT NUMBER  
0-621

NAME OF DRILLING FIRM  
Daniel Boone

Tylertown, ms

NAME & MAILING ADDRESS OF LANDOWNER  
Bobby Lee

143 Hwy 27 N

Tylertown, ms

WELL LOCATION: SEC. 21 TOWNSHIP 1 S RANGE 10 W

DISTANCE 5 MILES DIRECTION SW of NEAREST TOWN Tylertown

OTHER LANDMARK

WELL PURPOSE:  Home,  Irrigation,  Municipal,  Industrial,  Fish Pond, etc.

**PUMP DATA**

PUMP TYPE (Circle One):  
Submersible, Turbine,  Jet, Flowing Well,  
Other (Describe)

POWER TYPE (Circle One):  
 Electric, Tractor, Diesel, Gasoline, Butane,  
Other (Describe) H/P 1

Pump Capacity (GPM) 2 No. of Stages 40 Setting Depth Set FT.

PUMP TEST:  
Well yielded 8 GPM with  
a drawdown of \_\_\_\_\_ ft.  
after \_\_\_\_\_ hours of pumping

**WELL DATA**

Well Depth 65' Casing Diameter (In.) 2" Casing Length (FT.) 55'

Type of Casing PVC Hole Depth 65' Depth to Static Water Level 12'

TYPE OF COMPLETION: (Circle One or More):  
 Gravel Packed,  Underreamed,  Telescoped,  
 Natural Development,  Open Hole,  Other  
(Describe)

WELL GROUTED TO A DEPTH OF 8 FEET  
Type Grout (circle one):  Cement,  Bentonite, or Mix

**LOG DATA**

TYPE OF LOG RUN (Circle One):  No Log Run  
 Electric,  Gamma Ray,  Density,  Sonic,  Neutron,  
Other (Describe)

Name of Organization Running Log

**SCREEN DATA**

Diameter - Inches 2" Length - Feet 10' Slot Size - Inches .008

Screen Type PVC Sch. 40 Depth to Bottom - Feet 1'

**GEOLOGIC DATA (Office Use Only)**

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO	FORMATIONS (Continued)	FROM	TO
<u>Sand</u>	<u>0</u>	<u>4</u>			
<u>Clay</u>	<u>4</u>	<u>12</u>			
<u>Sand</u>	<u>12</u>	<u>65</u>			

IF MORE SPACE IS NEEDED, USE BACK

