

22-4252

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

COUNTY WELL LOCATED
Washington

WELL NUMBER **A 139** CODED

DATE WELL COMPLETED
8-9-89

PERMIT NUMBER
126C 0146A

NAME OF DRILLING FIRM
Layne-Central Co

Cleveland MS

CODED

P.O. Box 10631
Jackson, Mississippi 39209
WATER WELL DRILLERS LOG

NAME & MAILING ADDRESS OF LANDOWNER
Mr. Reggie Kellums
1976 McClain
Greenville, MS 38701

WELL LOCATION: SEC TOWNSHIP RANGE
12 19 N 8 8 W

DISTANCE DIRECTION NEAREST TOWN
1/2 Miles E of Peicilla

OTHER LANDMARK

WELL PURPOSE: Home Irrigation Municipal, Industrial, Fish Pond, etc.

PUMP DATA

PUMP TYPE (Circle One):
Submersible, Turbine Jet Flowing Well,
Other (Describe) _____

POWER TYPE (Circle One):
Electric, Tractor, Diesel Gasoline, Butane,
Other (Describe) _____ H/P _____

Pump Capacity (GPM) No. of Stages Setting Depth
2500 1 60 FT.

PUMP TEST

Well yielded NOT TESTED GPM with
a drawdown of _____ ft.
after _____ hours of pumping

WELL DATA

Well Depth Casing Diameter (In.) Casing Length (Ft.)
109 16 69

Type of Casing Hole Depth Depth to Static Water Level
Steel 109 21

TYPE OF COMPLETION: (Circle One or More):
Gravel Packed, Underreamed, Telescoped,
Natural Development, Open Hole, Other
(Describe) _____

Top of Lap Pipe or Reduction in Casing

FEET IF TELESCOPED OR MORE THAN ONE SCREEN: USE BACK PAGE

LOG DATA

TYPE OF LOG RUN (Circle One): No Log Run
Electric, Gamma Ray, Density, Sonic, Neutron,
Other (Describe) _____

Name of Organization Running Log

SCREEN DATA

Diameter - Inches Length - Feet Slot Size - Inches
16 40 .060

Screen Type Depth to Bottom - Feet
Steel 109

GEOLOGIC DATA (Office Use Only)

Surface Elev.	Geologic Unit	Unit Thickness	Depth to Top
Subs. SWL	Date	Analysis	Aquifer Test

Driller's Remarks

DESCRIPTION OF FORMATIONS ENCOUNTERED	FROM	TO
Clay	0	19
Fine Sand	19	50
Coarse Sand	50	65
C. Sand & GRAVEL	65	100
GRAVEL & Boulders	100	109

FORMATIONS (Continued)	FROM	TO
RECEIVED		
AUG 14 1989		
Department of Natural Resources Bureau of Land & Water Resources		

IF MORE SPACE IS NEEDED, USE BACK

