

May 05 08 05:12p

Bill Schultz

3355777

JAC P. 1

### State Well Report Part 1 - Driller's Log

Mississippi Department of Environmental Quality  
Office of Land and Water Resources  
P.O. Box 10631  
Jackson, MS 39289-0631  
(601)961-5210  
(601)354-6938 (fax)

County: Washington  
 Permit #: GW42433  
 Driller: Charles M. Nichols  
 Date drilling completed: 4-17-08

For Office Use Only:  
 Aquifer: \_\_\_\_\_  
 Well #: A-207  
 L. S. Elevation: \_\_\_\_\_  
 E-log #: \_\_\_\_\_

*State Law requires that this report be prepared by the license holder responsible for the work and filed with the Department at the above address within 30 days of completion of drilling of the well or borehole.*

<p><b>Information on Well Owner</b> (Landowner if borehole is not for a water well)</p> <p>Owner Name: <u>Stoneville R+D</u>          Mailing Address: <u>P.O. Box 341</u>  <u>Stoneville MS 38726</u>          City State Zip Code          Telephone No. ( ) _____</p>	<p><b>Well or Borehole Location</b></p> <p>Latitude: <u>33° 26' 53.3" N</u> Longitude: <u>90° 59' 62.5" W</u>  <u>38</u> <u>37</u>          Method of Lat/Long (Circle one): Conventional Survey,          USGS quad, <u>Hand-held GPS</u> Survey-grade GPS  <u>SW</u> 1/4 <u>SE</u> 1/4 Sec <u>35</u> Twn <u>19</u> Rng <u>8</u> W          Distance Direction Nearest Town  <u>1/4</u> Miles <u>East</u> of <u>Metcalfe</u></p>
--	---

**Well / Borehole Data**

Date drilling started: 4-17-08 Date drilling completed: 4-17-08 Hole depth: 100 Hole diameter: 20 in

Location of the source of any surface water used for drilling: Deer Creek  
 Method of dosing and volume of Chlorine used in drilling and development: # TH

Logs run (circle all applicable): No log run Electric Gamma Ray Density Sonic Neutron Other: \_\_\_\_\_  
 Name of organization running log(s): \_\_\_\_\_

Purpose of borehole (check one): Water Well  Geotechnical/Geological Investigation \_\_\_\_\_ Ground Source Heat Pump \_\_\_\_\_  
 Seismic Survey \_\_\_\_\_ Other (describe) \_\_\_\_\_  
*If drilling is not related to water well construction, skip the remainder of this block*

Purpose of Well (check one): Home \_\_\_\_\_ Industrial \_\_\_\_\_ Public Supply \_\_\_\_\_ Irrigation \_\_\_\_\_ Fish Culture  Other: \_\_\_\_\_

If a flowing well, method of flow regulation: Valve \_\_\_\_\_ Other (describe) \_\_\_\_\_

Static Water Level: 11 feet above or below (circle one) land surface Date measured: 4-17-08

Method of Measurement (circle one) steel tape electric tape air line other: \_\_\_\_\_

Well depth: 100 Well grouted to a depth of 10 feet Type of grout (circle one): Neat Cement Bentonite Mix

Casing length: 50 feet Casing diameter: 20 inches Type of casing: PVC

Screen length: 20 feet Screen diameter: 10 inches Type of screen: PVC

Screen slot size: .032 inches Setting depth: From 50 feet to 100 feet

Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development  
 Other (describe): \_\_\_\_\_

Top of lap pipe or reduction in casing: \_\_\_\_\_ feet. *If telescoped or more than one screen, describe on next page*

Form: OLWR-SWR-1A

RECEIVED  
MAY 05 2008  
BY: OLWR



May 05 08 05:12p

Bill Schultz

3355777

p. 3

### STATE WELL REPORT

#### Part 2

**Pump Installer's Completion Report**  
 Mississippi Department of Environmental Quality  
 Office of Land and Water Resources  
 P.O. Box 10631  
 Jackson, MS 39289-0631  
 (601)961-5210  
 (601)354-6938 (fax)

County: Washington  
 Permit #: \_\_\_\_\_  
 Driller: Charles M. Nichols  
 Date completed: 4-22-08  
 Copy information from block on Part 1

For Office Use Only:  
 Aquifer: \_\_\_\_\_  
 Well #: A-207  
 Elevation: \_\_\_\_\_

This part of the report must be completed by a licensed water well contractor or a licensed pump installer. A copy of Part 1 of the report must be attached and both parts filed with the Department at the above address within 30 days of well completion.

Well Owner Information	Well Location
Owner Name: <u>Stonerville R+D</u>	Latitude: <u>33°26.633N</u> Longitude: <u>090°59.625W</u>
Mailing Address: <u>P.O. Box 341</u>	Method of Lat/Long (check one): Conventional Survey _____
<u>Stonerville MS 38776</u>	USGS quad _____ Hand-held GPS <input checked="" type="checkbox"/> Survey-grade GPS _____
City State Zip Code	_____ 1/4 _____ 1/4 Sec _____ T _____ R _____
Telephone No. ( ) _____	Distance Direction Nearest Town
	<u>1/4 Miles east of Metcalfe</u>

Pump Type Circle one	Power Type Circle one
Air Lift Jet <input checked="" type="radio"/> Submersible	Diesel Engine Gasoline Engine Natural Gas
Bucket Piston Turbine	<input checked="" type="radio"/> Electric Motor Hand Tractor PTO
Centrifugal Rotary Flowing Well	Windmill Other (specify): _____
Other (specify): _____	Horse Power Rating of Motor: <u>20</u>
Date Pump Installed: <u>4-22-08</u>	Setting Depth: <u>60</u> feet
Rated Pump Capacity: <u>350</u> Gallons Per Minute	Number of Stages: <u>2</u>

Pump Test Data	Method of Measuring Water Level Circle one
Date Well Tested: _____	Air Line Electric Measuring Line <input checked="" type="radio"/> Steel Tape
Static Water Level (A): <u>11</u> Feet Below Land Surface	Other (specify): _____
Pumping Water Level (B): _____ Feet Below Land Surface	For flowing well, measured shut in head: _____ feet
Drawdown [(B) - (A)]: _____ Feet Below Land Surface	Well yielded _____ GPM with a drawdown of _____ feet after _____ hours of pumping
Test Pumping Rate: _____ Gallons Per Minute	
Duration of Pump Test (minimum 4 hours): _____ hours	

I HEREBY CERTIFY that the above statements are true to the best of my knowledge.

Charles M. Nichols 0-0667  
 Print Name of Pump Installer and License No. (if applicable)

Charles M. Nichols  
 Signature of Pump Installer

Form OLWR-SWR-1B

RECEIVED  
 MAY 05 2008  
 BY: OLWR