Grace wood - Farm Gene Stock

Part 1  Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 (601)961-5210 (601)354-6938 (fax)  State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.  Well Owner Information  Well Location  Well Location  Mailing Address: 37   Muchan Red.  Method of Lat/Long (circle one): Conventional Survey,				
Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631 L S. Elevation:  (601)961-5210 (601)354-6938 (fax)  State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.  Well Owner Information  Well Location  Owner Name Cracewood Forms  Latitude: 33				
Driller: J. NENCOTE Date drilling complete 21-07  Date drilling complete 21-07  Date drilling complete 21-07  State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.  Well Owner Information  Well Location  Owner Name Cracewood Torms  Latitude: 33				
Date drilling complete   Date drilling compl				
State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.  Well Owner Information  Owner Name Cracewood Torras  Latitude: 33				
State Law requires that this report be prepared by the driller in detail and filed with the Department within 30 days of completion of drilling of the well.  Well Owner Information  Well Location  Owner Name Cracewood Frams  Latitude: 33				
30 days of completion of drilling of the well.  Well Owner Information  Well Location  Owner Name Crecusor Franks  Latitude: 33				
Owner Name GRACEWOOD FRAMS Latitude: 33. 06. 10" Longitude 090.52'5				
Mailing Address: 137 / Mulesty RD. Method of Lat/Long (circle one): Conventional Survey,	2			
USGS quad, Hand-held GPS, Survey-grade GPS				
HOLLANDALE, MS. 38748 SE 1/4 Sec. 35 TWN ISN Rng TW				
Telephone Na 62-827-2825 Distance Different Nearest Town  Telephone Na 62-827-2825  5 Miles 5 of HOUANDALE				
W. II D. A.				
Well Data				
Purpose of Well (circle one) Home Industrial Public Supply Irrigation Fish Culture Other:				
Date well drilling started: 6-21-07 Date well drilling completed: 6-21-07				
If flowing, method of flow regulation: Valve Other (describe)				
Static Water Level:feet above or below (circle one) land surface Date measured:				
Method of Measurement (circle one) steel tape electric tape air line other:				
Hole depth: 113 Well depth: 110 Well grouted to a depth of 10 feet				
Type of grout (circle one): Cement Bentonite Mix				
Casing length: 80 feet Casing diameter: 10 inches Type of casing: PC				
Screen length: 30 feet Screen diameter: 10 inches Type of screen: pvc				
Screen slot size: 050 inches Setting depth: From 80 feet to 110 feet				
Type of completion (circle all applicable): Gravel packed Underreamed Telescoped Open hole Natural Development				
Other (describe):				
Top of lap pipe or reduction in casing:feet. If telescoped or more than one screen, describe on back of page	8			
Logs run (circle all applicable) No log run Electric Gamma Ray Density Sonic Neutron Other:				
Name of organization running log(s):				
Name of organization running log(s):				
Name of organization running log(s):  I certify that the well was drilled, constructed, and completed in accordance with all applicable requirements of the Mississi	ppi_			

Print Name of Water Well Contractor and License No.

RECEIVED

Signature of Water Well Contractor

JUL 17 2007

BYIOLWA

Ground Level	
30°1	10°' CASIM9 -80'

Description of Formations Encountered	From	То
- 10P Soil	0	0
Mixclay	10	40
Finesand	40	80
Coarse Sand	50	11

If more than one screen, show location of each on sketch

ketch the property layout and include the following: 1) the well location 2) any permanent structures on the property that may aid in locating the well; 3) any roads, power lines to the ritems that may aid in locating the property and the well;
4) indicate direction.
/AUT
$/(\omega)$
, /
PERCH 6
<b>/</b>
A DEPL
A VIE
Alexander of the second of the
(436)
War.
FURR RO.
1 70,
<b>\</b> .
lacksquare
TO ROLLHG POPEL
Landowner Name:

Signature of Water Well Contractor

## Permit #: 60 4200 2 Driller J. NEwComs Date completed: 0 2 1 0 7

## DIALE WELL REPURI

## Part 2 Pump Installer's Completion Report Mississippi Department of Environmental Quality Office of Land and Water Resources P.O. Box 10631 Jackson, MS 39289-0631

(601)961-5210 (601)354-6938 (fax)

	For Ottice Ose Otay:		
ity	Aquifer.		
	Well #: _ <b>Q</b> - //5		
	Elevation:		

This report should be prepared by the pump installer in detail and filed with the Department within 30 days of the installation of pump

installation of pump.	
Well Owner Information	Well Location
Owner Name RACELLOOD TORMS	Latitud 3-04-10 Longitud 90-52-52
Mailing Address: 137/ MURIHYRD.	Method of Lat/Long (circle one): Conventional Survey,
Hollandala Mc 38748 City State Zip Code	USGS quad, Hand-held GPS Survey-grade GPS  SE 1/4 SE 1/4 Sec 35 Twn/JN Rng 7W
Telephond 1862 - 827 - 2825	Distance Direction Nearest Town  S Miles of Hollangoles
Pump Type Circle one	Power Type Circle one
Air Lift Jet Submersible	Diesel Engine Gasoline Engine Natural Gas
Bucket Piston Turbine	Electric Motor Hand Tractor PTO
Centrifugal Rotary Flowing Well Other (specify):	Windmill Other (specify):  Horse Power Rating of Motor So
Date Pump Installed: 4/25/07  Rated Pump Capacity: 200 Gallons Per Minute	Setting Depth: 20 feet  Number of Stages:
Pump Test Data	Method of Measuring Water Level Circle one
Date Well Tested:  Static Water Level (A):  Pumping Water Level (B)  Feet Below Land Surface  Feet Below Land Surface	Air Line Electric Measuring Line Steel Tape  Other (specify):
Drawdown [(B) - (A)]:Feet Below Land Surface	For flowing well, measured shut in head:feet
Test Pumping Rate:Gallons Per Minute	Well yieldedGPM with a drawdown of
Duration of Pump Test (minimum 4 hours):hours	feet afterhours of pumping
I HEREBY CERTIFY that the above statements are true to the best the statement of Pump Installer and License No. (if applicable)	t of my knowledge.  Signature of Pump Installer

RECEIVED

JUL 17 2007 BY: OLWR