

# CODED

Winston  
P/4  
4-69  
U.S.G.S.  
0-

MISSISSIPPI  
 BOARD OF WATER COMMISSIONERS  
 416 North State Street  
 Jackson, Mississippi 39201

E-log 23

## WATER WELL DRILLERS LOG

date well completed 19 69 firm name Herndon Home Well Supply, Winston county well located Winston


LANDOWNER: Noxapate  
Down of Noxapate  
Noxapate, Miss.  
 (mailing address)

description of formations encountered	from
Red clay	0-8
Red sand	8-20
white sand	20-30
Blue clay	30-40
lignite	40-50
Blue clay	50-100
White sand	100-112
Blue clay	112-189
lignite	189-200
Blue clay	200-240
lignite	240-250
Blue clay	250-300
sand	300-311
Blue clay	311-438
sand	438-445
Blue clay	445-470
sand	470-535
Chalk (gray clay)	535-545
sand (gray)	545-590
gray clay	590-609
Art - Test	609

WELL LOCATION:  
 sec. 9 T 13 N R 12 E  
NW/4 NE/4 SW/4  
 (distance) miles (direction) of (nearest town)

WELL PURPOSE: Community  
 (home, irrigation, municipal, industrial)

- WELL COMPLETION DATA:
- diameter (inches) 8"
  - total depth (feet) 525'
  - static water level (feet) 155' below top of ground.
  - casing Steel, 1195' (material) (depth)  
8" (size) if telescope see back.
  - screen 20', 505' (length) (depth to top)  
4", stainless steel (size) (material)
  - pump 7 1/2, 91 (HP) (yield gpm)  
electric (type power)
  - electric log yes (yes or no)  
U.S.G.S. (organization running log)
  - how well bottom plugged \_\_\_\_\_



MAY 27 1969

DRILLERS REMARKS:

MISS. BD. OF  
 WATER COMM.

