

YAZOO
L23
4-24-74
E Log #253

MISSISSIPPI
BOARD OF WATER COMMISSIONERS
416 North State Street
Jackson, Mississippi 39201
WATER WELL DRILLERS LOG

CODED

4-24 1974 JEF COAT DRILLING CO YAZOO COUNTY
date well completed firm name county well located

LANDOWNER: CITY OF YAZOO CITY
SEWAGE TREATMENT PLANT #1
YAZOO CITY, MS. 39194
(mailing address)

WELL LOCATION:
6 11N sec. T N S R 2W E W
3 MILES SW of YAZOO CITY
(distance) (direction) (nearest town)

WELL PURPOSE: MUNICIPAL
(home, irrigation, municipal, industrial)

WELL COMPLETION DATA:
(1) diameter (inches) 8x4
(2) total depth (feet) 1064
(3) static water level (feet) 20 below top of ground.
(4) casing STEEL 230ft. (material) (depth)
4" (size) if telescope see back.
(5) screen 20 ft. 1040ft. (length) (depth to top)
4" STAINLESS STEEL (size) (material)
(6) pump 2 (HP) 70 (yield gpm)
AC (type power)
(7) electric log YES (yes or no)
MCS (organization running log)
(8) how well bottom plugged STEEL PIN WITH 1 1/8 inch ROD

description of formations encountered	from	to
clay and top soil	0	25
sand	25	34
sand and gravel	34	96
gravel	96	126
coarse sand	126	157
pea gravel	157	188
sand	188	219
sand and shell	219	249
shell	249	280
sand with shell stks	280	310
sand with shell stks	310	341
sand	341	373
sand	373	404
sand	404	435
sand with shell stks	435	465
shell	465	496
sand	496	526
sand	526	557
sand	557	588
shell	588	619
sand	619	649
sand with shell brks	649	680
shell with sand stks	680	710
shell with sand stks	710	740
shell brks	740	770
shell with sand brks	770	799
sand	799	830
sand	830	861
sand	861	892
sand	892	923
sand	923	954
sand	954	986
sand	986	1016
sand	1016	1040
sand	1040	1064

DRILLERS REMARKS:

JUL 24 1974
MISS. Bd. OF WATER COMMISSIONERS

If well telescopes please sketch and show depths.

GROUND LEVEL

SECTION _____

Please indicate well location X.

ADDITIONAL INFORMATION

If more than one screen,
show locations of each on sketch.