

WELL SCHEDULE

S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

JUL 5 1973

MASTER CARD RN

Record by JAC Source of data IP records Date 2-70 Map 53

State 4 County 28 (or town) 53

Latitude: 31° 10' 8" N Longitude: 091° 24' 42" W Sequential number: 1

Lat-long accuracy: 3' T. 6 S. R. 3 Sec. 10 NE NE

Local well number: F002AA1006N03W Other number: #2

Local use: 064 Owner or name: International Paper

Owner or name: INT PAPER CO Address: Wetzel Mill

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist N

Use of water: (A) Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, (S) Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other U

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. U

DATA AVAILABLE: Well data 70 Freq. W/L meas.: 71 Field aquifer char. 72

Hyd. lab. data: 73

Qual. water data; type: 3.0 USGS 74

Freq. sampling: 75 Pumpage inventory: 76

Aperture cards: 77

Log data: 78 79

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 228 ft Meas. 24 3

Depth cased: 148 ft Casing type: Steel Diam. 18 1/16 in 29 18

Finish: porous concrete, gravel w. (perf.), (screen), horiz. gallery, end, (P) open perf., (S) screen, (T) sd. pt., (W) shored, (X) open hole, (Z) other 31 G

Method Drilled: (A) air rot, (B) bored, (C) cable, (D) dug, (H) hyd jetted, (J) air rot., (P) percussion, (R) reverse, (T) trenching, (V) driven, (W) drive wash, (Z) other 32 R

Date Drilled: 10-24-49 9-4-49 Pump intake setting: 140 ft 36 38

Driller: Thomas Central Co

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, (Z) other 39 T Deep 40 Shallow

Power (type): diesel, (elec) gas, gasoline, hand, gas, wind; H.P. 150 W Trans. or meter no. 41

Descrip. MP Pump Stand about 1/2 ft above LSD, Alt. MP 106.38

Alt. LSD: 105 Accuracy: (source) 47 2

Water Level 100 ft above below MP; Ft. above below LSD 100 Accuracy: 52 0

Date meas: 5-27-54 5-5-4 Yield: 2000 gpm Method determined 61

Drawdown: 62 Accuracy: 63 Pumping period 64 hrs 65

QUALITY OF WATER DATA: Iron 69 Sulfate 70 Chloride 19 Hard. 269 72

Sp. Conduct 573 K x 10 4 Temp. 74 76 Date sampled 9/27 961 77 79

Taste, color, etc.

PUNCHED and VERIFIED

Well No. FZ

