

WELL SCHEDULE

J. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

JUL 5 1973

MASTER CARD RN

Record by JAC Source of data IP records Date 4/26/73 Map 2-15-70

State 28 County Alameda (or town) 01

Latitude: 31 29 30 N Longitude: 09 12 53 0 Sequential number: 1

Lat-long accuracy: 3 T. 6 S. R. 3 Sec. 14 NW SE

Local well number: F015B D1406 N03W Other number: #15

Local use: 064 961 Owner or name:

Owner or name: INTL PAPER CO Address:

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist N

Use of Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, water:

Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other N

Use of well: Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. W

DATA AVAILABLE: Well data 70 Freq. W/L meas.: 71 Field aquifer char. 72

Hyd. lab. data: 73

Qual. water data; type: partial USGS 74

Freq. sampling: 75 Pumpage inventory: yes no period: 76

Aperture cards: 77

Log data: 78 79

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 209 ft Meas. rept. accuracy 24 3

Depth cased; (first perf.) 149 ft Casing type: 18 in Diam. 29 30

Finish: porous gravel w. concret, (perf.), (screen), gallery, end, horiz. open perf., screen, sd. pt., shored, open hole, other 31

Method Drilled: air bored, cable, dug, hyd jetted, rot., air percussion, rotary, reverse trenching, driven, drive wash, other 32

Date Drilled: 1/52 952 Pump intake setting: 36 ft 38

Driller: Rayne Central Co name (L) (M) address

Lift (type): air, bucket, cent, jet, multiple, multiple, none, piston, rot, submerg, turb, other 39 Deep 40

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 150 Trans. or meter no. 41

Descrip. MP Pump sound about 3 ft above below LSD, Alt. MP 76.52

Alt. LSD: 74 Accuracy: (source) 47 2

Water Level 31 ft above below MP; Ft below LSD 31 Accuracy: 52 D

Date meas: 152 Yield: 2000 gpm Method determined 61

Drawdown: 32 ft Accuracy: 62 Pumping period 13 hrs 63

QUALITY OF WATER DATA: Iron 69 Sulfate 70 Chloride 5.1 Hard. 266 ppm

Sp. Conduct 499 K x 10⁶ 3 Temp. 73 Date sampled 9/27/61 74 75 76 77 79

Taste, color, etc. 78

PUNCHED and VERIFIED
ROLLA COMPUTATION BRANCH

Well No. F15

