

No elog info

GPSd 7/17/97 LM/BB

**WELL SCHEDULE**  
**OFFICE OF LAND AND WATER RESOURCES**

Fips 3

Well No. 6134

Log No. \_\_\_\_\_

Recorded by: PPhillips Data Source: Jennings/Drillers log Date: 5/4/95

County: Alcorn Permit No.: GW14920 DOH No.: 0020002-13

1/4: NE 1/4: NE 1/4: SE Sec.: 14 TWN: 2S RNG: 7E

Quad: Corinth Elevation: 443

Plotted on quad?: Y In field? Y From drillers log? \_\_\_\_\_ From permit? \_\_\_\_\_

Latitude: 34° 54' 30.8" Longitude: 88° 31' 32.0" GPS?  From quad? \_\_\_\_\_

Primary Aquifer: P12c Secondary Aquifer: \_\_\_\_\_

Use: Municipal Supply Well status: Active

Owner: City of Corinth

Address: \_\_\_\_\_

Telephone: \_\_\_\_\_ Local Well Name: City Well #19

Date drilled: 5/12/94 Driller: Herndon

Well depth: 474 Well diameter: 14" Pump type: Turbine

Power type: Electric Pump capacity: 320 GPM

Casing: 443' 6.0" (14"); 120-60(8") 0 to 383

Screen interval(msl): 60' to -37' (land surface): 383 to 474'

Type of logs: Drillers Log interval: \_\_\_\_\_

Initial water level(l/s): 127.5 Date: 5/12/1994

Measuring point description: \_\_\_\_\_

---

Water Quality Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Level Data? Y Source: City of Corinth Reliability: Good

Pump Test Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Use Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

---

Water level data

---

This area for location map and notes