



MISSISSIPPI DEPARTMENT OF ENVIRONMENTAL QUALITY

WELL SCHEDULE

FIPS: 5

WELL: N116

LOG NO.: \_\_\_\_\_

Recorded by: PPhillips Data Source: Permit Driller's log Date: 3/19/02  
County: Amite Permit No.: GW15089 DOH No.: 0030004-04  
Quad: Liberty Elevation: 360'  
1/4: NW 1/4: SE 1/4: NW 1/4: NE Sec.: 9 T: 2N R: 4E

Plotted on quad?  In field?  From drillers log? \_\_\_\_\_ From permit? \_\_\_\_\_

Latitude: \_\_\_\_\_ Longitude: \_\_\_\_\_ GPS?  From Quad? \_\_\_\_\_

Primary aquifer: MOCN Secondary aquifer: \_\_\_\_\_

Use: MU Well status: Active Local well name: Gayle St well

Owner: Town of Liberty

Date completed: 7/29/96 Driller: Griner Drilling Well depth: 240 Hole Depth: 280

Pump type: Turbine Power type: Electric Pump capacity: 300 gpm

Casing interval: 0-190 Casing length: 190' Casing diameter: 18"

Casing interval: ?-200 Casing length: ? Casing diameter: 10"?

Screen interval: 200-240 Screen length: 40 Screen diameter: 10

Screen interval: \_\_\_\_\_ Screen length: \_\_\_\_\_ Screen diameter: \_\_\_\_\_

Type of logs: \_\_\_\_\_ Log interval: \_\_\_\_\_

Initial water level: \_\_\_\_\_ Date: \_\_\_\_\_ M.P. description: \_\_\_\_\_

Water Quality Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Level Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Pump Test Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Use Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_