

**WELL SCHEDULE  
FOR  
THE OFFICE OF LAND AND WATER RESOURCES**

Fips: 7

Well: D23

Log No: \_\_\_\_\_

Recorded by: PPhillips Data Source: Drillers log, Permit Date: 7/23/98

County: Atala Permit No.: GW14900 DOH No.: 0040006-03

Quad: McCool Elevation: 482

1/4: NW 1/4: SE 1/4: SE 1/4: SW Sec.: 35 T: 16N R: 9E

Plotted on quad?  In field?  From drillers log? \_\_\_\_\_ From permit? \_\_\_\_\_

Latitude: 33° 11' 55.1" Longitude: 89° 20' 44.1" GPS?  From quad? \_\_\_\_\_

Primary Aquifer: WLCXL Secondary Aquifer: \_\_\_\_\_

Use: MU Well status: Active Local Well Name: \_\_\_\_\_

Owner: Town of McCool

Date completed: 6/26/95 Driller: Herndon Well & Supply Well depth: 753 Hole depth: 765

Pump type: Turbine Power type: Electric Pump capacity: 250gpm

Screen interval: 692 - 753 Screen length: 61' Screen diameter: 6"

Screen interval: \_\_\_\_\_ Screen length: \_\_\_\_\_ Screen diameter: \_\_\_\_\_

Casing interval: 0 - 692(?) Casing length: 692' Casing diameter: 10"

Casing interval: 630 - 692 Casing length: 32 Casing diameter: 6"

Type of logs: E-log Log interval: \_\_\_\_\_

Initial water level(l/s): 136.22 Date: 6/26/95 Measuring point description: \_\_\_\_\_

Water Quality Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Level Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Pump Test Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Use Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water level data

---

This area for location map and notes

---