

**WELL SCHEDULE  
FOR  
THE OFFICE OF LAND AND WATER RESOURCES**

Fips: 7

Well: U14

Log No: \_\_\_\_\_

Recorded by: PPhillips Data Source: Drillers log; permit Date: 7/23/98

County: Attala Permit No.: GW14844 DOH No.: 0040011-02

Quad: Four Corners Elevation: 517

1/4: \_\_\_\_\_ 1/4: \_\_\_\_\_ 1/4: SW 1/4: NW Sec.: 25 T: 13N R: 9E

Plotted on quad?: ☒ In field? ☒ From drillers log? \_\_\_\_\_ From permit? \_\_\_\_\_

Latitude: 32° 57' 24.9" Longitude: 89° 20' 14.8" GPS? \_\_\_\_\_ From quad? \_\_\_\_\_

Primary Aquifer: MUW Secondary Aquifer: \_\_\_\_\_

Use: IA Well status: Active Local Well Name: \_\_\_\_\_

Owner: Zama Water Association

Date completed: 5/1/96 Driller: Herndon Well depth: 490 Hole depth: 625

Pump type: Turbine Power type: Electric Pump capacity: 135 gpm

Screen interval: 460 - 490 Screen length: 30 Screen diameter: 6"

Screen interval: \_\_\_\_\_ Screen length: \_\_\_\_\_ Screen diameter: \_\_\_\_\_

Casing interval: 0 - 460 Casing length: 460 Casing diameter: 10"

Casing interval: 393 - 460 Casing length: 67 Casing diameter: 6"

Type of logs: E-log Log interval: \_\_\_\_\_

Initial water level(l/s): 170.25 Date: 5/1/96 Measuring point description: \_\_\_\_\_

Water Quality Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Level Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Pump Test Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

Water Use Data? \_\_\_\_\_ Source: \_\_\_\_\_ Reliability: \_\_\_\_\_

---

Water level data

---

This area for location map and notes