

RLB 10/9/03

GW06344
0060016-01

Rosedale Quad

10/78

TRANSMITTED FOR ADP

Recorded by WTE JAC
Date 8/74 11/2/73

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

1/77

Well No. F101
E-Log No. 55
County Bolivar

Site ID 335122091013601 R=0* T=AM* 2=W* V

GEN. SITE DATA

Data reliab. 3=CU* Report. agency 4=USGS* Dist. 6=28* 7=28* Co. 8=011*

Lat. Long. 9=335122* 10=0910136* Well No. 12=F101*

Location 13=SWSE S 09T 23N R 08W* Alt. 16=150* 147

Hyd. Unit (OWDC) 20=* Date 21=0612711974*

Well use 23=W* Water Use 24=P* Hole depth 27=505* Well depth 28=487*

WL 30=27* Date 31=0612711974* Source 33=D*

Status 273=*

MU SPRT

OWNER

R=158* T=AM* Date 159#0612711974* Owner No. #4

Owner 161=ROSEDALE*

FIELD QW

R=192* T=AM* Date 193#* Temp. 196#00010* 197=*

R=192* T=AM* Date 193#* Cond. 196#00095* 197=*

R=192* T=AM* Date 193#* pH 196#00400* 197=*

CONSTR.

R=58* T=AM* 59#1* Date 60=0612711974* Remarks

Drlg. 63=064* Name SINGER LAYNE Method 65=H* Finish 66=G*

CASING

R=76* T=AM* 59#1*

Top csng. 77# 0* Bot. csng. 78=427* Diam. 79#12*

R=76* T=AM* 59#1*

Top csng. 77#* Bot. csng. 78=* Diam. 79#*

OPENINGS

R=82* T=AM* 59#1* Top 83#427* Bottom 84=487*

Type 85=S* Diam. 87=12* Size 88=*

R=82* T=AM* 59#1* Top 83#* Bottom 84=*

Type 85=* Diam. 87=* Size 88=*

FIELD

R=134 146* T=AM* 147#1* Q 150=* O/S 272=*

LIFT

R=42* T= A M * Lift type 43# T * Intake 44= * Power type 45= E *

Date 38= 06/27/1974 * H.P. 46= 4.0. *

LOGS

R=198* T= A M * Log 199# D * Top 200= 0. * Bot 201= 5.0.5. *

R=198* T= A M * Log 199# E * Top 200= 1.0. * Bot 201= 5.0.5. *

R=189* T= A M * E Log No. 190# 055 * 191= M I S S D I S T *

ANAL.

R=114* T= A M * Year 115# * Type 120= * *

AQUIFERS

R=90* T= A M * 256# 1 * Top 91= 4.0.5. * Bot 92= 4.9.0. *

Unit ID 93= 1.2.4.C.C.K.F. * Name of Unit Cockfild

R=90* T= A M * 256# 1 * Top 91= * Bot 92= * *

Unit ID 93= * Name of Unit

HYDRAULICS

R=98* T= A M * 99# 1 * Unit tested 100= * *

R=105* T= A M * 99# 1 * Test No. 106# * *

107= * Transmissivity (gal/d)/ft

108= * Hydraul. cond. (gal/d)/ft²

110= * Storage coeff. Boundaries