

WRD Exp. (GW)
April 1966

Well No. D70
E 109 # 78

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

MBOWC

PUNCELOON
ROLLA MISSISSIPPI

Record by P.E. Grantham Source of data MSGS E. log Date 2-19-68 Map

State Mississippi County Forrest (or town) 18

Latitude: 31 20 35 N Longitude: 08 9 18 20 Sequential number: 1

Lat-long accuracy: 20 T. 4 S. R. 13 Sec. 4 NE 1/4, NE 1/4

Local well number: D070BA0404N13W Other number: B & M

Local use: 161078 Owner or name: Murry Envelope Co. #2

Owner or name: MURRY ENVELOPE CO Address: Hattiesburg Miss

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist N

Use of water: (A) Air cond, (B) Bottling, (C) Comm, (D) Dewater, (E) Power, (F) Fire, (G) Dom, (H) Irr, (I) Med, (J) P S, (K) Rec, (L) Stock, (M) Instit, (N) Unused, (O) Reppure, (P) Recharge, (Q) Desal-P S, (R) Desal-other, (S) Other N

Use of well: (A) Anode, (B) Drain, (C) Seismic, (D) Heat Res, (E) Obs, (F) Oil-gas, (G) Recharge, (H) Test, (I) Unused, (J) Withdraw, (K) Waste, (L) Destroyed W

DATA AVAILABLE: Well data Freq. W/L meas.: Field aquifer char.

Hyd. lab. data:

Qual. water data; type:

Freq. sampling: Pumpage inventory: yes no, period:

Aperture cards: yes

Log data: DE

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 422 ft 422 Meas. rept accuracy 3

Depth cased: 402 ft 402 Casing type: Steel; Diam. 6 3/4 in 8

Finish: porous concrete, gravel w. concrete, (perf.), (screen), (galler), (horiz. open perf.), (screen, sd. pt., shored, open hole), other S

Method: (A) air bored, (B) cable, (C) dug, (D) hyd jetted, (E) rot., (F) air reverse, (G) trenching, (H) driven, (I) drive wash, (J) other H

Date Drilled: 6-19-68 968 Pump intake setting: 33 ft 36

Driller: S & R Drilling Co. Palat Miss

Lift (type): (A) air, (B) bucket, (C) cent, (D) jet, (E) multiple, (F) multiple, (G) none, (H) piston, (I) rot, (J) submerg, (K) turb, (L) other S Deep Shallow

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 10 4 Trans. or meter no. 4

Descrip. MP 140 ft below LSD. Alt. MP 140 Accuracy: (source) 4

Water Level 21 ft above MP; Ft below LSD 21 Accuracy: D

Date meaas: 768 Yield: 300 gpm 158 Method determined 61

Drawdown: 62 ft Accuracy: 65 Pumping period: 66 hrs 68

QUALITY OF WATER DATA: Iron ppm 69 Sulfate ppm 70 Chloride ppm 71 Hard. ppm 72

Sp. Conduct K x 10 73 Temp. °F 74 76 Date sampled 77 79

Taste, color, etc. 79

liner
9/93
4"
Well No. D70

