

HBRG

E 30

FORM 9-1642 (1-68)

Well No. E 30

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by J.S. Source of data BOWC Date 12/69 Map

State MS County (or town) Forrest 118

Latitude: 31 15 00 N Longitude: 08 91 11 2 Sequential number: 1

Lat-long accuracy: 3 T. S. R. W. Sec 34 B & M

Local well number: E 020 CA 34 04 N 12 W Other number:

Local use: 307 Owner or name:

Owner or name: ANN FAIRLEY Address: Rt. 2, Hattiesburg

Ownership: (C) County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist P

Use of water: (A) Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec. H

(S) Stock, Instit, Unused, Reprasure, Recharge, Desal-P S, Desal-other, Other H

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. W

DATA AVAILABLE: Well data Freq. W/L meas.: Field aquifer char.

Hyd. lab. data:

Qual. water data; type:

Freq. sampling: Pumpage inventory: no. period:

Aperture cards:

Log data:

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 85 ft Meas. rept. accuracy 3

Depth cased; (first perf.) 80 ft Casing type: PVC; Diam. in 2

Finish: (C) porous concrete, (F) gravel w. (perf.), (G) gravel w. (screen), (H) horiz. gallery, (O) open end, (P) perf., (S) screen, (T) sd. pt., (W) shored, (X) open hole, (Z) other 3

Method: (A) air, (B) bored, (C) cable, (D) dug, (H) hyd, (J) jetted, (P) air percussion, (R) reverse, (T) trenching, (V) driven, (W) drive wash, (Z) other H

Date Drilled: 9-6-69 Pump intake setting: 36 ft

Driller: Rayborn name address

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, (Z) other Deep Shallow 40

Power (type): (nat) diesel, elec, gas, gasoline, hand, gas, wind; (LP) H.P. Trans. or meter no. 41

Descrip. MP 150 ft above LSD, Alt. MP 47

Alt. LSD: 42 ft above MP; Ft below LSD 42 Accuracy: 0

Date meas: 9-6-69 Yield: 969 gpm Method determined 61

Drawdown: 62 ft Accuracy: 65 hrs 66

QUALITY OF WATER DATA: Iron 69 ppm Sulfate 70 ppm Chloride 71 ppm Hard. 72 ppm

Sp. Conduct 73 K x 10 74 Temp. 75 °F Date sampled 76

Taste, color, etc. 77

PRINTED AND VERIFIED

Well No.

E 30

