

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD #

Record by Reed Source of data Well Date 6-7-39 Map Nicholson Quad

State 28 County (or town) Hancock 23

Latitude 30 25 48 N Longitude: 08 93 84 2 Sequential number: 1

Lat-long accuracy: 3 7 17 24 NE NE

Local well number: E009AA24017S17W Other number: B & M

Local use: 024 Owner or name: Truman, W. Hancock Co

Owner or name: MISS. STATE HWY Address: now Miss. State Hwy Dept.

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist S

Use of water: (A) Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, (S) Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other H

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. W

DATA AVAILABLE: Well data 0 Freq. W/L meas.: 0 Field aquifer char. 0

Hyd. lab. data: 0

Qual. water data; type: P

Freq. sampling: 0 Pumpage inventory: no, period: 0

Log data: 0

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 767 ft Meas. rept accuracy 6

Depth cased: (first perf.) 727 ft Casing type: 0; Diam. 4 in

Finish: (C) porous concrete, (F) gravel w. (perf.), (G) gravel w. (screen), (H) horiz. gallery, (O) open end, (P) perf., (S) screen, (T) sd. pt., (W) shored, (X) open hole, (Z) other S

Method Drilled: (A) air rot, (B) bored, (C) cable, (D) dug, (H) hyd jetted, (J) air rot., (P) percussion, (R) reverse, (T) crenching, (V) driven, (W) drive wash, (Z) other H

Date Drilled: 928 Pump intake setting: 0 ft

Driller: J. Butler name address

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, other N Deep 0 Shallow 0

Power (type): (nat) diesel, elec, gas, gasoline, hand, gas, wind; H.P. 0 Trans. or meter no. 0

Descrip. MP 0 ft above below LSD, Alt. MP 0

Alt. LSD: 36 Accuracy: (source) 4

Water Level: 23 ft above below MP; Ft below LSD +21 Accuracy: A

Date meas: 664 Yield: 0 gpm Method determined 0

Drawdown: 0 ft Accuracy: 0 Pumping period: 0 hrs

QUALITY OF WATER DATA: Iron ppm 0 Sulfate ppm 0 Chloride ppm 0 Hard. 0

Sp. Conduct K x 10⁶ 0 Temp. °F 79 Date sampled 6/3/64 664

Taste, color, etc. 0

