

WELL SCHEDULE

E 109 # 28

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by PEG Source of data Dr. obs Date _____ Map _____

State 28 County (or town) Harrison 24

Latitude: 30 24 10 N Longitude: 08 05 33 6 Sequential number: 7

Lat-long accuracy: 2 7 9 Sec 29 NE SW

Local well number: M0067C2907S09W Other number: # 7

Local use: 088028 Owner or name: City of Biloxi

Owner or name: BILOXI Address: Hospital well

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist M

Use of water: (A) Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, (S) Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other P

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed, (W) W

DATA AVAILABLE: Well data Freq. W/L meas.: Field aquifer char:

Hyd. lab. data:

Qual. water data; type:

Freq. sampling: Pumpage inventory: period:

Aperture cards:

Log data: DE

12/4/89
WL=46.2

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 463 Meas. 3

Depth cased: 384 Casing type: 14 Diam. 14

Finish: (C) porous concrete, (F) gravel w. (perf.), (G) gravel w. (screen), (H) horiz. gallery, (O) open end, (P) perf., (S) screen, (T) sd. pt., (W) shored, (X) open hole, (Z) other S

Method Drilled: (A) air rot, (B) bored, (C) cable, (D) dug, (H) hyd rot., (J) jetted, (P) air percuss, (R) reverse, (T) trenching, (V) driven, (W) drive wash, (Z) other H

Date Drilled: 10/63 963 Pump intake setting: 145

Driller: C. T. SWITZER

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, other 7 Deep 39 Shallow 40

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 75 Trans. or meter no. 41

Descrip. MP 15 Accuracy: 3

Alt. LSD: 15 Accuracy: 3

Water Level: -9 ft above below MP; Ft below LSD 9 Accuracy: 7

Date meas: 063 Yield: 5 gpm 550 Method determined 61

Drawdown: 120 Accuracy: 65 Pumping period: 66 hrs 68

QUALITY OF WATER DATA: Iron ppm 69 Sulfate ppm 70 Chloride ppm 71 Hard. ppm 72

Sp. Conduct 73 K x 10 74 Temp. 76 Date sampled 77 79

Taste, color, etc. 78

PUNCHED and VERIFIED
ROLLA COMPUTATION BRANCH

Well No. M6

