

White Supt. 366-2681

9-185  
(October 1950)  
203  
9.24  
193.76

UNITED STATES  
DEPARTMENT OF THE INTERIOR  
GEOLOGICAL SURVEY  
WATER RESOURCES DIVISION

210  
16.03  
193.97

WELL SCHEDULE

Date June 16, 1954 Field No. \_\_\_\_\_  
Record by Hurvey Office No. H 64  
Source of data Mr. White, Sup. Bldg North well #1

\*1. Location: State Miss County Hinds

Map Jackson Quad  
NE, SE, SW  $\frac{1}{4}$  SW  $\frac{1}{4}$  sec. 26 T 6 S R 1 E W

2. Owner: University Hospital Address N. State + Woodrow  
Tenant \_\_\_\_\_ Address Wilson, Jackson  
Driller Hayne Central Address Hwy 80 W.

3. Topography \_\_\_\_\_  
4. Elevation 332+ ft. above MSL  
5. Type: Dug, drilled, driven, bored, jetted 6 1954  
6. Depth: Rept. 78.2 ft. Meas. \_\_\_\_\_ ft.  
7. Casing: Diam. 10 in. to 6 in., Type \_\_\_\_\_  
Depth 716 ft., Finish 40' screen G.P.  
8. Chief Aquifer Top of screen @ 716 ft. from \_\_\_\_\_ ft. to \_\_\_\_\_ ft.  
Others 193.97 1st @ 193.76 2nd at 11:40 9/19/58


9. Water level 166 ft. rept 6 1954 above 1954 below  
Breather on east side of which is 2 1/2 ft. above below surface

10. Pump: Type W. turb. Capacity 300 G.M.  
Power: Kind Elec. Horsepower 30

11. Yield: Flow \_\_\_\_\_ G.M., Pump 300 G.M., Meas. Rept. Est.  
Drawdown 40-60 ft. after 2 1/2 hours pumping acc to Bldg. Supt. 300 G.M.

12. Use Dom?, Stock, PS., RR., Ind., Irr., Obs. Air Cond. + other hosp  
Adequacy, permanence Adequate used

13. Quality \_\_\_\_\_ Temp \_\_\_\_\_ °F.  
Taste, odor, color \_\_\_\_\_ Sample Yes No  
Unfit for \_\_\_\_\_

14. Remarks: (Log, Analyses, etc.) Add 1 ppm. Cl.  
497' between wells.

500-165-7-72

DEPARTMENT OF AGRICULTURE  
 GEOLOGICAL SURVEY  
 WATER RESOURCES DIVISION

WELL NO. \_\_\_\_\_  
 DATE OF DATA \_\_\_\_\_

Case No. \_\_\_\_\_  
 Field No. \_\_\_\_\_

State \_\_\_\_\_  
 Locality \_\_\_\_\_  
 W.L. 218-21.11 = 196.59 - 2.0 = 194.59 LSD

Owner \_\_\_\_\_  
 Address \_\_\_\_\_  
 Driller \_\_\_\_\_


- 1. To \_\_\_\_\_
- 2. To \_\_\_\_\_
- 3. To \_\_\_\_\_
- 4. To \_\_\_\_\_
- 5. To \_\_\_\_\_
- 6. To \_\_\_\_\_
- 7. To \_\_\_\_\_
- 8. To \_\_\_\_\_
- 9. To \_\_\_\_\_
- 10. To \_\_\_\_\_
- 11. To \_\_\_\_\_
- 12. To \_\_\_\_\_
- 13. To \_\_\_\_\_
- 14. To \_\_\_\_\_
- 15. To \_\_\_\_\_
- 16. To \_\_\_\_\_
- 17. To \_\_\_\_\_
- 18. To \_\_\_\_\_
- 19. To \_\_\_\_\_
- 20. To \_\_\_\_\_

Pressure tank operation  
 All year operation

700' about

RECEIVED  
 1 to 1000 Hojo no.  
 DATE

DEPARTMENT OF ENVIRONMENTAL QUALITY - OLWR  
PUBLIC SUPPLY WELLS PROJECT

GPS LOG

USER NAME(S): STEWART/EVERETT DATE: 6/16/94  
UNIT DEQ #: 84090 FILE #: R061616C  
HEALTH DEPT. #: 250034-01 ELEV. 330  
USGS #: H64 OLWR #: GW3368  
OWNER: U. MED. CENTER Quad: JACKSON  
LOCATION: SW SW S 26 T 6 N R 1 E COUNTY: HINDS  
LOCATION DESCRIPTION: S/OF PHYSICAL PLANT  
E/OF ADDIE M. BRYDE CENTER FOR BLIND  
CASING DIA: \_\_\_\_\_ PUMP TYPE & SIZE: 75 HP TURBINE  
GPS FIELD LOCATION: LAT. 32° 19.737' LONG. 90° 10.291'  
GPS CORRECTED LOCATION: LAT. 32.328837 LONG. 90.174538  
REMARKS: \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_

