

July 1935
Revised

UNITED STATES *Not in use 1955*
DEPARTMENT OF THE INTERIOR *S.W.P.C.*
GEOLOGICAL SURVEY
WATER RESOURCES BRANCH

WELL SCHEDULE

Date *July 17*, 19*40* Field No. *1*
Record by *W.M. Foster* Office No. *624*
Source of data *Mrs. J. E. Cummings, Supt. of Waterworks*

1. Location: State *Miss* County *Hawamba*

Map *NE 1/4 NE 1/4 sec. 25 T 9 S R 8 E*

2. Owner: *City of Fulton* Address *Fulton Miss.*

Tenant _____ Address _____

Driller *Mr. John Webb* Address *Belden, Miss*

3. Topography *Terrace of Tombigbee*

4. Elevation *320* ft. above below

5. Type: Dug, drilled driven, bored, jetted *19.32*

6. Depth: Rept. *164* ft. Meas. _____ ft.

7. Casing: Diam. *8* in., to _____ in., Type _____

Depth *164* ft., Finish *10' Perf. pipe*

8. Chief Aquifer *Tuscaloosa gravel* from _____ ft. to _____ ft.

Others _____

9. Water level _____ ft. rept. _____ above _____ below

_____ which is _____ ft. above _____ below surface

10. Pump: Type *Pomana deepwell turbine* Capacity *125* G. M.

Power: Kind *electric* Horsepower *5*

11. Yield: Flow _____ G. M., Pump *85* G. M., Meas., Rept. Est.

Drawdown _____ ft. after _____ hours pumping _____ G. M.

12. Use: Dom., Stock, RR., Ind., Irr., Obs. _____

Adequacy, permanence _____

13. Quality *High iron content* Temp *63 3/4* °F.

Taste, odor, color _____ Sample Yes No

Unfit for *Domestic use till after treatment*


14. Remarks: (Log, Analyses, etc.) *Treated by aeration. Lime*

filter being installed. Static head reported -20' in 1940

drawdown reported 50' after pumping 85 gpm for 1/2 hr

Fulton uses about 20,000 pounds

14. W. ...
13. ...
12. ...
11. ...



10. ...
9. ...
8. ...
7. ...
6. ...
5. ...
4. ...
3. ...
2. ...
1. ...

MAILED SEP-20-1933 BY MAIL ROOM
U.S. DEPARTMENT OF JUSTICE
FEDERAL BUREAU OF INVESTIGATION
WASHINGTON, D. C.

