

6/77 WIO

TRANSMITTED

Recorded by

BEW / WTD
9/77 11/77

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

3/78

Well No.

P380

E-Log No.

County

JACKSON

Site ID

30 23 06 08 83 20 80 1

R=0*

T=A*

2=W*

Data reliab.

3=C*

Report. agency

4=USGS*

Dist.

6=28*

7=28*

Co.

8=059*

Lat.

Long./

9=30 23 06 *

10=08 83 20 8 *

Well No.

12='P 380' *

Location

13= S 36 T 07 S R 06 W *

Alt.

16= 15. *

Hyd. Unit (OWDC)

20= *

Date

21= 01 / 01 / 1962 *

Well use

23= W *

Water Use

24= H *

Hole depth

27= . *

Well depth

28= 264. *

WL

30= 101. *

Date

31= 09 / 14 / 1977 *

Source

33= S *

Status

273 = Y *

Project No.

5= *

R=158*

T= A *

Date

159# 01 / 01 / 1962 *

Owner No.

Owner

161= HARRY L KREBBS *

R=192*

T= A *

Date

193# / / / *

Temp.

196#00010*

197= . *

R=192*

T= A *

Date

193# 09 / 14 / 1977 *

Cond.

196#00095*

197= 690. *

R=192*

T= A *

Date

193# 09 / 14 / 1977 *

pH

196#00400*

197= 7.8 *

R=58*

T= A *

59# 1*

Date

60= 01 / 01 / 1962 *

Remarks

Drig.

63= *

Name

Colville

Method

65= H *

Finish

66= S *

R=76*

T= A *

59# 1*

Top csng.

77# 0. *

Bot. csng.

78= 110. *

Diam.

79# 4. *

R=76*

T= A *

59# 1*

Top csng

77# 110. *

Bot. csng.

78= 254. *

Diam.

79# 2. *

R=82*

T= A *

59# 1*

Top

83# 254. *

Bottom

84= 264. *

Type

85= S *

Diam.

87= 2. *

Size

88= . *

R=82*

T= A *

59# 1*

Top

83# . *

Bottom

84= . *

Type

85= . *

Diam.

87= . *

Size

88= . *

R= 146 *

T= A *

147# 1 *

Q

150= 20. *

Q/S

272= . *

134 flows 146 pumped

LIFT

R=42* T= A * Lift type 43# S * Intake 44= * Power type 45= E *

Date 38= 01/01/1962 * H.P. 46= 3. *

LOGS

R=198* T= A * Log 199# * Top 200= * Bot 201= *

R=198* T= A * Log 199# * Top 200= * Bot 201= *

R=189* T= A * E Log No. 190# * 191= M I S S I D I S T *

ANAL.

R=114* T= A * Year 115# * Type 120= *

AQUIFERS

R=90* T= A * 256# 1 * Top 91= * Bot 92= *

Unit ID 93= I 21 G R M F * Name of Unit

R=90* T= A * 256# 1 * Top 91= * Bot 92= *

Unit ID 93= * Name of Unit

HYDRAULICS

R=98* T= A * 99# 1 * Unit tested 100= * 103= *

R=105* T= A * 99# 1 * Test No. 106# *

107= * Transmissivity (gal/d)/ft

108= * Hydraul. cond. (gal/d)/ft²

110= * Storage coeff. Boundaries

R=121* T= * Yr Begin 122# *

Water Level Data Collection (1)

(Krebbs trailer Park)
(5303 Telephone RD.)