

U3

Couldnt find well - omit

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION
ROLLA, MISSOURI
PORTERVILLE 216-A

MASTER CARD

Record by P.E. Grantham Source of data MBOWC Date 1-20-69 Map

State Miss County (or town) Kemper 28 35

Latitude: 32° 37' 43" N Longitude: 088° 28' 37" W Sequential number: 1

Lat-long accuracy: 2 T 9 S, R 18 W, Sec 17 SW t, SW t, NE t

Local well number: 4003DA1709N18E Other number: B & M

Local use: 055 Owner or name: Mrs. Eva K. Hatcher

Owner or name: EVA K. HATCHER Address: Rt 2 Porterville, Miss

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist P

Use of water: (A) Air cond, Bottling, Comm, Dewster, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, (S) Stock, Instit, Unused, Reprressure, Recharge, Desal-P S, Desal-other, Other H

Use of well: (A) Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed. W

DATA AVAILABLE: Well data Freq. W/L meas.: Field aquifer char.

Hyd. lab. data:

Qual. water data; type: USGS 8/70

Freq. sampling: Pumpage inventory: no. period:

Aperture cards:

Log data: No Log

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 1368 ft Meas. 3

Depth cased: (first perf.) 1284 ft Casing type: Steel; Diam. 4x2 in 4

Finish: porous concrete, gravel w. (perf.), gravel w. (screen), horiz. gallery, open end, other P

Method Drilled: (A) air rot, (B) air bored, (C) cable, (D) dug, (H) hyd rot., (J) jetted, (P) air percussion, (R) reverse, (T) trenching, (V) driven, (W) drive wash, other H

Date Drilled: 8-12-68 9168 Pump intake setting: ft

Driller: Terry Drilling Co

Lift (type): (A) air, (B) bucket, (C) cent, (J) jet, (L) multiple, (M) multiple, (N) none, (P) piston, (R) rot, (S) submerg, (T) turb, other 5 Deep Shallow

Power (type): diesel, lec, nat gas, gasoline, hand, gas, wind; H.P. 3/4 5 Trans. or meter no.

Descrip. MP ft above ft below LSD, Alt. MP

Alt. LSD: ~300 300 Accuracy: (source) 6

Water Level 91 ft above MP; Ft below 91 LSD Accuracy: Method

Date meas: 868 Yield: gpm hrs hrs hrs

Drawdown: ft Accuracy: Pumping period hrs

QUALITY OF WATER DATA: Iron 2.6 Sulfate Chloride 5,000 Hard.

Sp. Conduct 17,900 K x 10⁶ 8 Temp 23°C Date sampled 8/70

Taste, color, etc. Water very salty Cond = greater than 8,000

Well No.

U3