

TRANSMITTED FOR ADP

6/77 WTD

Recorded by JAC

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

3/84

Well No. R11

Date 6/28/78

E-Log No. _____

County PANOLA

DC BATESVILLE

Site ID 3 4 1 8 5 3 0 8 9 5 6 4 6 0 2 R=0* T=A*

2=W* **PUNCHED**

GEN. SITE DATA

Data reliab. 3=C* Report. agency 4=USGS* Dist. 6=28* 7=28* Co. 8=107*

Lat. _____ Long. 9=3 4 1 8 5 3 10=0 8 9 5 6 4 6 Well No. 12=R 0 1 1

Location 13=N W S W S 0 9 T 0 9 S R 0 7 W Alt. 16=2 4 5

Hyd. Unit (OWDC) 20=0 8 0 3 0 2 0 1 Date 21=0 4 1 0 1 1 9 6 4

Well use 23=W Water Use 24=P Hole depth 27=1 2 0 8 Well depth 28=1 0 8 5

WL 30=1 6 8 Date 31=0 4 1 0 1 1 9 6 4 Source 33=D

Status 273= Project No. 5=

OWNER

R=158* T=A* Date 159# 0 4 1 0 1 1 9 6 4 Owner No. _____

Owner 16# B A T E S V I L L E

FIELD QW

R=192* T=A* Date 193# 1 1 0 7 1 1 9 8 5 Temp. 196#00010* 197=2 4 . 0

R=192* T=A* Date 193# / / Cond. 196#00095* 197=

R=192* T=A* Date 193# 1 1 0 7 1 1 9 8 5 pH 196#00400* 197=8 . 1

CONSTR.

R=58* T=A* 59# 1* Date 60=0 4 1 0 1 1 9 6 4 Remarks _____

Drig. 63=0 6 4 Name _____ Method 65=A Finish 66=B

LAYNE CENTRAL

CASING

R=76* T=A* 59# 1*

Top csgn. 77# 0 . Bot. csgn. 78=1 0 4 0 . Diam. 79# 1 6 .

R=76* T=A* 59# 1*

Top csgn. 77# Bot. csgn. 78= Diam. 79#

OPENINGS

R=82* T=A* 59# 1* Top 83# 1 0 4 0 . Bottom 84=1 0 8 5 .

Type 85=S Diam. 87=1 0 . Size 88=

R=82* T=A* 59# 1* Top 83# Bottom 84=

Type 85= Diam. 87= Size 88=

YIELD

R=146* T=A* 147# 1* Q 150=7 5 0 . Q/S 272=

134 flows 146 pumped

-42* T= A * Lift type 43# T * Intake 44= * Power type 45= E *
 Date 38= 0.4/0.0/19.64 * H.P. 46= 7.5 *

R=198* T= A * Log 199# 0 * Top 200= 10.0 * Bot 201= 1.20.8.1 *

R=198* T= A * Log 199# E * Top 200= 10.0 * Bot 201= 1.20.8.1 *

R=189* T= A * E Log No. 190# 0.1.9 * 191= M I S S D I S T *

R=114* T= A * Year 115# * Type 120= *

R=90* T= A * 256# 1 * Top 91= 1.0.20.0 * Bot 92= 1.0.8.6 *

Unit ID 93= 1.2.4.W.L.C.X.L * Name of Unit

R=90* T= A * 256# 1 * Top 91= * Bot 92= *

Unit ID 93= * Name of Unit

R=98* T= A * 99# 1 * Unit tested 100= * 103= *

R=105* T= A * 99# 1 * Test No. 106# *

07= * Transmissivity (gal/d)/ft

108= * Hydraul. cond. (gal/d)/ft²

110= * Storage coeff. Boundaries

R=121* T= * Yr Begin 122# *

Water Level Data Collection (1)

Color = 15 units (H₂S smell)

Treatment

Alorine

4-13-73 @ 1100

water level = 90.66' below lsd N

300,000 gallon
EIG TANK

