

700
TRANSMITTED FOR ADP

6/77 WTO

Recorded by JAC

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

3/86

Well No. R11

Date 6/28/78

E-Log No. _____

County PANOLA

DC BATESVILLE

Site ID 3.4.1.8.5.3.0.8.9.5.6.4.6.0.2 R=0* T= A *

2=W* **PUNCHED**

GEN. SITE DATA

Data reliab. 3=C*^CU Report. agency 4=USGS* Dist. 6=28* 7=28* Co. 8=1.0.7*

Lat. _____ Long. 9=3.4.1.8.5.3* 10=0.8.9.5.6.4.6* Well No. 12=R.0.1.1*

Location 13=N.W.S.W.S.0.9.T.0.9.S.R.0.7.W* Alt. 16=24.5*

Hyd. Unit (OWDC) 20=0.8.0.3.0.2.0.1* Date 21=0.4.1.0.0.1.1.9.6.4*

Well use 23=W* Water Use 24=P* Hole depth 27=120.8* Well depth 28=108.5*

WL 30=16.8* Date 31=0.4.1.0.0.1.1.9.6.4* Source 33=D*

Status 273= _____* Project No. 5= _____*

OWNER

R=158* T= A * Date 159#0.4.1.0.0.1.1.9.6.4* Owner No. _____

Owner 16# BATESVILLE

FIELD QW

R=192* T= A * Date 193#1.1.0.7.1.1.9.8.5* Temp. 196#00010* 197=24.0*

R=192* T= A * Date 193# _____* Cond. 196#00095* 197= _____*

R=192* T= A * Date 193#1.1.0.7.1.1.9.8.5* pH 196#00400* 197=8.1*

CONSTR.

R=58* T= A * 59#1* Date 60=0.4.1.0.0.1.1.9.6.4* Remarks _____

Drlg. 63=0.6.4* Name _____ Method 65=H* Finish 66=15*

LAYNE CENTRAL

CASING

R=76* T= A * 59#1* _____

Top csng. 77#0.* Bot. csng. 78=1.040* Diam. 79#1.6*

R=76* T= A * 59#1* _____

Top csng. 77# _____* Bot. csng. 78= _____* Diam. 79# _____*

OPENINGS

R=82* T= A * 59#1* Top 83#1.040* Bottom 84=1.085*

Type 85=S* Diam. 87=1.0* Size 88= _____*

R=82* T= A * 59#1* Top 83# _____* Bottom 84= _____*

Type 85= _____* Diam. 87= _____* Size 88= _____*

YIELD

R=146* T= A * 147# 1 * Q 150=7.50* Q/S 272= _____*

134 flows 146 pumped

=42* T= A * Lift type 43# T * Intake 44= * Power type 45= E *

Date 38= 04/00/1964 * H.P. 46= 75. * *

R=198* T= A * Log 199# 0 * Top 200= * Bot 201= 1,208. * *

R=198* T= A * Log 199# E * Top 200= 0. * * Bot 201= 1,208. * *

R=189* T= A * E Log No. 190# 019 * 191= M I S S D I S T * *

R=114* T= A * Year 115# * Type 120= * *

R=90* T= A * 256# 1 * Top 91= 1,020. * * Bot 92= 1,086. * *

Unit ID 93= 124WLCXL * Name of Unit

R=90* T= A * 256# 1 * Top 91= * * Bot 92= * *

Unit ID 93= * Name of Unit

R=98* T= A * 99# 1 * Unit tested 100= * 103= * *

R=105* T= A * 99# 1 * Test No. 106# * *

07= * Transmissivity (gal/d)/ft

108= * Hydraul. cond. (gal/d)/ft²

110= * Storage coeff. Boundaries

R=121* T= * Yr Begin 122# * *

Water Level Data Collection (1)

Color = 15 units (H₂S smell)

Treatment

Chlorine

4-13-73 @ 1100

water level = 90.66' below level N

300,000 gallon

EIG TANK



