

WRD Exp. (GW)  
April 1966

Well No. F2

WELL SCHEDULE

E. Log # 45  
MR  
Stacow

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by PE. Grantham Source of data MBH Date 6/2/68 Map Poplarville, Miss

State Mississippi County Pearl River

Latitude: 30° 52' 14" N Longitude: 091° 32' 57" W Sequential number: 1

Local well number: F002B D1302 S16W Other number: B & M

Local use: 074095 Owner or name: Sunny Oak Water Ass

Owner or name: SUNNY OAK W A Address: NW of Poplarville

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist N

Use of water: (A) Air cond, (B) Bottling, (C) Comm, (D) Dewater, (E) Power, (F) Fire, (G) Dom, (H) Irr, (I) Med, (J) Ind, (K) P S, (L) Rec, (M) Stock, (N) Instit, (O) Unused, (P) Repressure, (Q) Recharge, (R) Desal-P S, (S) Desal-other, (T) Other P

Use of well: (A) Anode, (B) Drain, (C) Seismic, (D) Heat Res, (E) Obs, (F) Oil-gas, (G) Recharge, (H) Test, (I) Unused, (J) Withdraw, (K) Waste, (L) Destroyed U

DATA AVAILABLE: Well data 0 Freq. W/L meas: 0 Field aquifer char. 0

Hyd. lab. data: 0

Qual. water data; type: MBH USS complete 6/12/74

Freq. sampling: 0 Pumpage inventory: 0

Aperture cards: 0

Log data: E. Log 10-1260

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 1010 Meas. rept accuracy 3

Depth cased: 960 Casing type: 6, 4 in

Finish: (C) concrete, (F) gravel w. (perf.), (G) gravel w. (screen), (H) horiz. open gallery, (I) end, (J) other S

Method: (A) air rot, (B) bored, (C) cable, (D) dug, (E) hyd jetted, (F) air rot., (G) percussion, (H) rotary, (I) reverse, (J) trenching, (K) driven, (L) drive wash, (M) other H

Date Drilled: 3-68 968 Pump intake setting: 0 ft

Driller: Neil Lumpkin name address

Lift (type): (A) air, (B) bucket, (C) cent, (D) jet, (E) multiple, (F) multiple, (G) none, (H) piston, (I) rot, (J) submerg, (K) turb, (L) other S Deep 0 Shallow 40

Power (type): (A) diesel, (B) elec, (C) gas, (D) gasoline, (E) hand, (F) gas, (G) wind, (H) H.P. 20 Y Trans. or meter no. 0

Descrip. MP 33.5 335 Accuracy: (source) 4

Water Level: 215 Accuracy: D

Date meas: 468 Yield: 150 gpm Method determined: 0

Drawdown: 0 Accuracy: 0 Pumping period: 0 hrs

QUALITY OF WATER DATA: Iron 0.7 Sulfate 0 Chloride 0 Hard. 12 Sp. Conduct 2 Temp. 25.6 Date sampled 674

Taste, color, etc. 0

Yes  
DEC 16 1974

PUNCHED and VERIFIED  
A COMPUTATION BRANCH

Let  
with  
V. 1968

Well No.

F2

