

81

9-185—July 1935
Revised

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
WATER RESOURCES BRANCH

City # 1

WELL SCHEDULE

Date July 26, 1946 Field No. 4
Record by W.M. Foster Office No. F1
Source of data Mr. L.E. Goodger

Rechecked 6-23-54
543
City # 1 on Park St.
Pump set 211:

1. Location: State Miss County Prentiss
Map Boonville Quad. Ad Boonville water works
SW 1/4 SW 1/4 1/4 sec. 10 T 5 N R 7 W

2. Owner: Peoples Water Service Co Address Baltimore Md
Tenant City of Boonville Address Boonville, Miss
Driller Layne Central Address Memphis, Tenn

3. Topography S

4. Elevation 500 ft. above
below June 1938

5. Type: Dug, drilled driven, bored, jetted 1931

6. Depth: Rept. 419 ft. Meas. _____ ft.

7. Casing: Diam. 12 in., to 6 in., Type Steel
Depth 419 ft., Finish Gravel wall 60' xgs

8. Chief Aquifer Fataw sand From 350 ft. to 419 ft.
Others _____

9. Water level 157 ft. rept. 1932 above 15d
meas. below surface
which is _____ ft. above
below surface

10. Pump: Type Layne deep well Turbine Capacity 150 G. M.
Power: Kind Electric Horsepower 20


11. Yield: Flow _____ G. M., Pump 150 G. M., Meas., Rept. Est.
Drawdown _____ ft. after _____ hours pumping _____ G. M.

12. Use: Dom., Stock, PS, RR., Ind, Irr., Obs.
Adequacy, permanence _____

13. Quality _____ Temp 63 1/2 °F.
Taste, odor, color odor and color in file (1942) Sample Yes 6-23-54
Unfit for _____ No ENB

14. Remarks: (Log, Analyses, etc.) Pumping level reported at 150' when drilled. City uses av. 90,000 range 70,000 to 100,000. Treated with lime to remove Ca.

log in files ENB



LA BOONEVILLE QUAD

