

0610032-001

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Recprd. by EJH Source of data _____ Date _____ Map Whitfield

State 28 County (or town) 61

Latitude: 32^{deg} 14^{min} 56^{sec} N Longitude: 09^{deg} 00^{min} 04^{sec} W Sequential number: 4

Lat-long accuracy: 3 T. 5 S. R. 2 W. Sec. 26 NW SW NE NW/SW

Local well number: K039BC2605N02E Other number: #4

Local use: 064 Owner or name: Miss State Hospital

Owner or name: MISS STATE HOSP Address: Whitfield

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist 5

Use of Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, Destroyed

water: (S) (T) (U) (V) (W) (X) (Y) (Z) 7

Use of well: Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed 2

DATA AVAILABLE: Well data Freq. W/L meas: Field aquifer char:

Hyd. lab. data: _____

Qual. water data: type: _____

Freq. sampling: _____ Pumpage inventory: _____ no, period: _____

Aperture cards: _____ yes _____

Log data: _____ CCKF _____

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: _____ ft 865 Meas. rept. accuracy 6

Depth cased (first perf.): _____ ft 785 Casing type: _____; Diam. 12x8 in 12

Finish: porous concrete, gravel w. (perf.), gravel w. (screen), horiz. gallery, open end, other 5

Method: (A) air bored, (B) cable, (C) dug, (D) hyd jetted, (E) air percussion, (F) reverse, (G) trenching, (H) driven, (I) wash, (J) other 4

Date Drilled: 9:49 Pump intake setting: 240 ft 30

Driller: Layne Central name (L) (M) (N) (P) (R) (S) (T) (U) (V) (W) (X) (Y) (Z) address _____

Lift (type): air, bucket, cent, jet, multiple, multiple, nose, piston, rot, submerg, turb, other 7 Deep Shallow

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 60 Trans. or meter no. 60

Descrip. MP 332 above ft below LSD, Alt. MP _____

Alt. LSD: 332 Accuracy: (source) Bar 7

Water Level: _____ ft above MP; _____ ft below LSD 180 Accuracy: _____ 6

Date meas: 9:56 Yield: _____ gpm 250 Method determined _____

Drawdown: _____ ft Accuracy: _____ Pumping period _____ hrs _____

QUALITY OF WATER DATA: Iron 14 ppm Sulfate 69 ppm Chloride 38 ppm Hard. 2 ppm

Sp. Conduct 657 K x 10 4 Temp. 82 Date sampled 158

Taste, color, etc. _____

PUNCHED AND VERIFIED
ROLLA-COMPUTATION BRANCH

Well No.

K39

Bldg 44

