

9-185
(October 1950)

UNITED STATES
DEPARTMENT OF THE INTERIOR
GEOLOGICAL SURVEY
WATER RESOURCES DIVISION

650 DUE
5 OF WELL
No. 3

Abandoned

WELL SCHEDULE

Date *July 20* 19*56* Field No. *4*
Record by *J.N. Shows* Office No. *K40*
Source of data *H.L. Jones*

1. Location: State *MISS* County *RANKIN*
Map *Hosp. #5 Nurses Home*
SE SW 1/4 SW 1/4 sec. 26 T. 5 S. R. 2 E
2. Owner *Whitfield Corp* Address _____
Tenant _____ Address _____
Driller *Ratliff* Address _____
3. Topography _____
4. Elevation _____ ft. above _____
_____ ft. below _____
5. Type: Dug, drilled, driven, bored, jetted 19*56*
6. Depth: Rept. *920* ft. Meas. _____ ft.
7. Casing: Diam. *2 1/2* in. to _____ in., Type _____
Depth *840* ft. Finish *SCREEN 80'±*
8. Chief Aquifer *Sparta* From _____ ft. to _____ ft.
Others *Probably 499 in 1956 (see back of #5)*
9. Water level *196* ft. Rept. *1956* above _____
_____ ft. below _____
_____ which is _____ ft. above _____
_____ ft. below surface
10. Pump: Type *Turntable* Capacity _____ G.M.
Power: Kind *Elec.* Horsepower *60*
Guaranteed
11. Yield: Flow *100* G.M., Pump _____ G.M. Meas. (Rept) Est. _____
Drawdown _____ ft. after _____ hours pumping *332* G.M.
12. Use: Dom., Stock, PS., RR., Ind., Irr., Obs. *H2SP, Test*
Adequacy, permanence _____
13. Quality *Good* Temp _____ °F
Taste, odor, color _____ Sample Yes _____ No _____
Unfit for _____
14. Remarks: (Log, Analyses, etc.) _____

DEPARTMENT OF ENVIRONMENTAL QUALITY - OLWR
PUBLIC SUPPLY WELLS PROJECT

GPS LOG

USER NAME(S): Phillips / Hardin DATE: 7/2/96
UNIT DEQ #: _____ FILE #: B070218I
HEALTH DEPT. #: 610032-04 ELEV. 327' 318
USGS #: K40 OLWR #: _____
OWNER: MS State Hospital QUAD: Whitfield
LOCATION: NW/SW S 26 T 5N R 2E COUNTY: Rankin
LOCATION DESCRIPTION: sw of Bldg 52 (maintenance
shop)
CASING DIA: _____ PUMP TYPE & SIZE: Pump gone
GPS FIELD LOCATION: LAT. 32° 14' 37.0" N LONG. 90° 04' 13.8" W
GPS CORRECTED LOCATION: LAT. 32.24345246 LONG. 90.07133065
REMARKS: P+ A → pump pulled, no tag

02- OBS well

610095-01

2948 1 SE (JACKSON SE) 777

