

MISSISSIPPI DEPARTMENT OF NATURAL RESOURCES

Bureau of Land and Water Resources

COUNTY WELL LOCATED Simpson	
WELL NUMBER	CODED
DATE WELL PLUGGED 11-8-96	

PERMIT NUMBER no permit required, 4"
NAME OF DRILLING FIRM Layne-Central
Jackson, MS

P. O. Box 10631
Jackson, Mississippi 39209
WATER WELL PLUGGING
DECOMMISSIONING

NAME & MAILING ADDRESS OF LANDOWNER Boswell Regional Center			
P.O. Box 128			
Sanatorium, MS 39112			
WELL LOCATION	SEC	TOWNSHIP	RANGE
	27(?)	1North	5East
DISTANCE	DIRECTION	NEAREST TOWN	
186'	from power plant chimney,		
OTHER LANDMARK 16' from c/1 of gravel road			
WELL PURPOSE: Home, Irrigation, Municipal, Industrial, Fish Pond, etc. Municipal (State Institution)			

NAME OF WELL CONTRACTOR WHO DRILLED THE WELL unknown		
NAME OF LANDOWNER WHEN WELL WAS DRILLED Sanatorium		
WELL DATA		
Well Depth 126'	Casing Diameter (In.) 4"	Casing Length (Ft.) 86'
Type of Casing steel	Hole Depth 126'	Depth to Static Water Level 52'
DATE WELL COMPLETED 1963		

29' from nearest corner of block building at water plant.
This well has USGS # K003, Source of water...Citronell

DESCRIBE HOW THE WELL OR HOLE WAS PLUGGED: (AMOUNT OF CASING AND/OR SCREEN THAT WAS REMOVED, OR LEFT IN HOLE, MATERIAL USED IN PLUGGING, ETC.)
Pump pulled completely,
This well was tested to see if it could produce useable water. At only 2 gpfdd specific yield, it was decided to abandon this well.
A 1" line was run to approximately 85 feet. A cement slurry was mixed and injected at this point. Slurry weight was about 14 ppg. When returns were noted, 2 sections of cement line were removed. The cement slurry was again injected until returns noted. The well was allowed to sit for 1 hour and capped off to the top
of the foundation. The job was checked 3 days later and capped off a final time.

I CERTIFY THAT THE WELL WAS PLUGGED OR ABANDONED IN ACCORDANCE WITH THE STATE OF MISSISSIPPI REGULATIONS	
_____ SIGNATURE <i>Ralph E. Hayes, P.E.</i> Ralph E. Hayes P.E.	_____ DATE 11-11-96