1/81 WTO

(RECORDED) COULONT FIND ORIGINAL SCHEDULE

Recorded by ND

Date 7-19-85

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

Well No. P13

E-Log No.

County SMITH

Site ID 5 3147460893A2601 19 | R=0* | T=A* | 2=W*

Data reliab. 3=C* CU | Report. agency 4=USGS* | Dist. 6=28* 7=28* | Co. 8=129*

GEN. SITE DATA

Lat. Long./ 9=3147460* 10=0893426* | Well No. 12=P013*

Location 13=NWNE S35 T10N R16W* | Alt. 16=450.*

Hyd. Unit(OWDC) 20=* | Date 21=01/01/1977*

Well use 23=W* | Water Use 24=P* | Hole depth 27=*. | Well depth 28=241.*

WL 30=115.* | Date 31=01/01/1977* | Source 33=D*

Status 273=* | Project No. 5=*

OWNER

R=158* T=A* | Date 159#01/01/1977* | Owner No.

Owner 161#OKLAHOMA WATER*

FIELD GW

R=192* T=A* | Date 193#*/*/* | Temp. 196#00010* 197=*

R=192* T=A* | Date 193#*/*/* | Cond. 196#00095* 197=*

R=192* T=A* | Date 193#*/*/* | pH 196#00400* 197=*

CONSTR.

R=58* T=A* | 59#1* | Date 60=01/01/1977* | Remarks

Drlg. 63=DCA* | Name Layne | Method 65=H* | Finish 66=G*

CASING

R=76* T=A* | 59#1*

Top csgn. 77#0.* | Bot. csgn. 78=195.* | Diam. 79#12.*

R=76* T=A* | 59#1*

Top csng 77#~~195~~ 160.* | Bot. csgn. 78=201.* | Diam. 79#8.*

OPENINGS

R=82* T=A* | 59#1* | Top 83#201.* | Bottom 84=241.*

Type 85=S* | Diam. 87=8.* | Size 88=.030*

R=82* T=A* | 59#1* | Top 83#*. | Bottom 84=*.

Type 85=* | Diam. 87=*. | Size 88=*.

YIELD

R=146* T=A* | 147#1* | Q 150=~~300~~ 400.* | Q/S 272=*.

134 flows 146 pumped

5' bowl

LIFT.

R=42* | T= A * | Lift type 43# T * | Intake 44= 220 * | Power type 45= E *

Date 38= 01/01/1977 * | H.P. 46= 40. *

LOGS

R=198* | T= A * | Log 199# * | Top 200= * | Bot 201= *

R=198* | T= A * | Log 199# * | Top 200= * | Bot 201= *

R=189* | T= A * | E Log No. 190# * | 191= M I S S D I S T *

ANAL.

R=114* | T= A * | Year 115# * | 117= * | 120= *

AQUIFERS

R=90* | T= A * | 256# 1 * | Top 91= * | Bot 92= *

Unit ID 93= * | Name of Unit

R=90* | T= A * | 256# 1 * | Top 91= * | Bot 92= *

Unit ID 93= * | Name of Unit

HYDRAULICS

R=98* | T= A * | 99# 1 * | Unit tested 100= * | 103= *

R=105* | T= A * | 99# 1 * | Test No. 106# * |

107= * | Transmissivity (gal/d)/ft

108= * | Hydraul. cond. (gal/d)/ft^2

110= * | Storage coeff. | Boundaries

R=121* | T= * | Yr Begin 122# * | Network 258 # *

Water Level Data Collection (1)

8/85

Tested 400 gpm @ 375 28" dd.