

WELL SCHEDULE

ELOG-146

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by TNShow Source of data Driller Date 3-10-67 Map SMITH CO. Hwy.

State MISSISSIPPI 28 County (or town) SMITH 65

Latitude: 31 50 14 N Longitude: 08 9 27 08 Sequential number: 1

Lat-long accuracy: 2 T. 10 S. R. 14 Sec. 18, NW $\frac{1}{4}$, NW $\frac{1}{4}$, SW $\frac{1}{4}$

Local well number: P0068C1810N14W Other number: B & M

Local use: 028 46 267 19 Owner or name: FELLOWSHIP WATER ASSOC.

Owner or name: FELLOWSHIP WATER ASSOC. Address: Test Hole TAYLORSVILLE, MISS.

Ownership: County, Fed Gov't, City, (N) Corp or Co., Private, State Agency, Water Dist N

Use of water: Air cond, Bcttling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, (P) P S, Rec.

Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other P

Use of well: Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, (Z) Withdraw, Waste, (Z) Destroyed

DATA AVAILABLE: Well data 1 Freq. W/L meas.: 0 Field aquifer char. Z

Hyd. lab. data: 0

Qual. water data; type: Complete Chemical Anal. 3-1-67

Freq. sampling: 0 Pumpage inventory: no, period: 0

Aperture cards: 0

Log data: E-109 8-705 D E

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 212 ft 212 Meas. 3

Depth cased: 192 ft 192 Casing type: 10 gal. - rest black iron Diam. 4x2 in 4

Finish: porous concrete, gravel v. gravel w. horlz. open perf., (S) screen, sd. pt., shored, open hole, other S

Method Drilled: (H) air bored, cable, dug, (H) hyd rot, jetted, air percussion, rotary, reverse trenching, driven, drive wash, other H

Date Drilled: 2-23-67 967 Pump intake setting: 0 ft 0

Driller: C.P. Clark Drilling Co., Rt. #2, Laurel, Miss.

Lift (type): air, bucket, cent, jet, multiple, multiple, none, piston, rot, (S) submerg, turb, other S Deep D Shallow 0

Power (type): diesel, (elec) elec, gas, gasoline, hand, gas, wind; H.P. 3HP T Trans. or meter no. 0

Descrip. MP Top of 4" casing 1.23 ft above LSD. Alt. MP 0

Alt. LSD: 370 370 Accuracy: 0

Water Level 98.75 ft above MP; Ft. 98.75 LSD 98.75 Accuracy: 0

Date meas: 2-28-67 267 Yield: 60 gpm 60 Method determined D

Drawdown: 0 ft 0 Accuracy: 0 Pumping period 5 hrs 5

QUALITY OF WATER DATA: Iron 0 ppm Sulfate 0 ppm Chloride 0 ppm Hard. 0 ppm

Sp. Conduct 0 K x 10 0 Temp. 66 °F 66 Date sampled 367

Taste, color, etc.

Well No.

R64

