

Recorded by EHB JAC
Date 8/54 4/14/77

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

6/77 Well No. 56
E-Log No. _____
County TIPPAM

GEN. SITE DATA

Site ID 344514088581502 R=0* T= A * 2=W*

Data reliab. 3=C^C Report. agency 4=USGS* Dist. 6=28* 7=28* Co. 8=139 *

Lac. _____

Long. / 9=344514 * 10=0885815 * Well No. 12=5006 *

Locat. 13=SE S 14 T 04 S R 03 E * Alt. 16=510 * 400 500

Hyd. Unit (OWDC) 20= * Date 21=0010011946 *

Well use 23=W * Water Use 24=P * Hole depth 27= * Well depth 28=970 *

WL 30=1.75 * Date 31=0910011954 * Source 33=D *

Status 273=Y *

OWNER

R=158* T= A * Date 159#0010011946 * Owner No. _____

Owner 161=RIPLEY *

AMERICAN BUILT RIGHT

FIELD QW

R=192* T= A * Date 193# / / * Temp. 196#00010* 197= *

R=192* T= A * Date 193# / / * Cond. 196#00095* 197= *

R=192* T= A * Date 193# / / * pH 196#00400* 197= *

CONSTR.

R=58* T= A * 59#1* Date 60=0010011946 * Remarks _____

Drig. 63=06A * Name _____ Method 65=H * Finish 66=G *

LAYNE CENTRAL

CASING

R=76* T= A * 59#1*

Top csng. 77# 0 * Bot. csng. 78= 910 * Diam. 79# 12 *

R=76* T= A * 59#1*

Top csng 77# * Bot. csng. 78= * Diam. 79# *

OPENINGS

R=82* T= A * 59#1* Top 83# 910 * Bottom 84= 970 *

Type 85=S * Diam. 87= 8 * Size 88= *

R=82* T= A * 59#1* Top 83# * Bottom 84= *

Type 85= * Diam. 87= * Size 88= *

YIELD

R= 146 * T= A * 147# 1* Q 150= 250 * Q/S 272= *

134 flows 146 pumped

LIFT
R=42* T= A * Lift type 43# T* Intake 44= * Power type 45= E*
Date 38- 00/00/1946* H.P. 46= 3.5.*

LOGS
R=198* T= A * Log 199# D* Top 200= 8.6.6.* Bot 201= 9.9.4.*
R=198* T= A * Log 199# * Top 200= * Bot 201= *
R=189* T= A * E Log No. 190# * 191= M I S S D I S T *

ANAL.
R=114* T= A * Year 115# * Type 120= *

AQUIFERS
R=90* T= A * 256# 1 * Top 91= 8.9.5.* Bot 92= 9.8.3.*
Unit ID 93= 211 LOFF * Name of Unit Coffee Sand.
R=90* T= A * 256# 1 * Top 91= * Bot 92= *
Unit ID 93= * Name of Unit

HYDRAULICS
R=98* T= A * 99# 1 * Unit tested 100= *
R=105* T= A * 99# 1 * Test No. 106# *
107= * Transmissivity (gal/d)/ft
108= * Hydraul. cond. (gal/d)/ft²
110= * Storage coeff. Boundaries