

REPLACEMENT

U. S. DEPT. OF THE INTERIOR GEOLOGICAL SURVEY

WATER RESOURCES DIVISION
APR 22 1975

TRANSMITTED FOR ADP

MASTER CARD

Record by J.A. Callahan Source of data Obs. Driller Date 6-10-66 Map County

State Miss. County Walthall 28 74

Latitude: 31 19 44 N Longitude: 09 01 32 4 Sequential number: 7

Lat-long accuracy: 2 4 10 8 SW NW

Local well number: A003CD0804N10E Other number: B & M

Local use: 029 Owner or name: United Gas-Pumping Sta.

Owner or name: UNITED GAS CO Address: Tylertown, Miss.

Ownership: County, Fed Gov't, City, Corp or Co, Private, State Agency, Water Dist N

Use of Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, P S, Rec, water: (H)

Stock, Instit, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other (P)

Use of Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, Withdraw, Waste, Destroyed well: (W)

DATA AVAILABLE: Well data Freq. W/L meas.: None Field aquifer char.

Hyd. lab. data:

Qual. water data; type: Complete Chemical Analysis

Freq. sampling: Original Pumpage inventory: no period:

Aperture cards:

Log data:

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 226 ft 226 Meas. rept. accuracy 6

Depth cased: 206 ft 206 Casing type: Bronze Diam. 06 in 6

Finish: porous concrete, gravel w. (perf.), gravel w. (screen), horiz. gallery, open end, perf., screen, sd. pt., shored, open hole, other (S)

Method Drilled: air rot, bored, cable, dug, hyd rot, jetted, percuss, rotary, air reverse wash, driven, drive wash, other (H)

Date Drilled: 9/5/63 Pump intake setting: ft

Driller: Fitzgerald M E Comb. Miss.

Lift (type): air, bucket, cent, jet, multiple, multiple, none, piston, rot, submerg, turb, other (J) (D) Deep Shallow

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 5 Trans. or meter no.

Descrip. MP none above ft below LSD. Alt. MP

Alt. LSD: 350 Accuracy: 6

Water Level: -78' ft above below MP; Ft below LSD 78 Accuracy: reported

Date meas: 1951 51 Yield: 30 gpm 30 Method determined

Drawdown: ft Accuracy: Pumping period hrs

QUALITY OF WATER DATA: Iron 0.05 Sulfate 0.2 Chloride 3.5 Hard. 5

Sp. Conduct 25 K x 10⁶ Temp. 69 °F 69 Date sampled 8-17-66 866

Taste, color, etc.

Well No.

A3

