

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by WTR Source of data Driller - Obs Date 2-20-69 Map _____

State 28 County Washington (or town) 76

Latitude: 33 26 33 N Longitude: 097 02 25 Sequential number: 1

Lat-long accuracy: 2 18 8 2 SE NE NE (NE, NE, S)

Local well number: D113 DB 3318 NO 8 W Other number: _____

Local use: 064066 Owner or name: City of Greenville

Owner or name: GREENVILLE Address: _____

Ownership: (C) (F) (M) (N) (P) (S) (W) M

Use of water: (A) (B) (C) (D) (E) (F) (H) (I) (M) (N) (P) (R) P

Use of well: (S) (T) (U) (V) (W) (X) (Y) (Z) W

DATA AVAILABLE: Well data Freq. W/L meas.: Field aquifer char.

Hyd. lab. data: _____

Qual. water data; type: _____

Freq. sampling: _____ Pumpage inventory: no; period: _____

Aperture cards: _____ yes

Log data: E-log 100' - 680' DE

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 666 ft Meas. rept 3

Depth cased: (first perf.) 590 ft Casing type: steel ; Diam. 18x12 in 18

Finish: (C) (F) (G) (H) (I) (J) (K) (L) (M) (N) (O) (P) (Q) (R) (S) (T) (U) (V) (W) (X) (Y) (Z) S

Method Drilled: (A) (B) (C) (D) (E) (F) (G) (H) (I) (J) (K) (L) (M) (N) (O) (P) (Q) (R) (S) (T) (U) (V) (W) (X) (Y) (Z) H

Date Drilled: 969 Pump intake setting: _____ ft _____

Driller: Jayne Central, Memphis

Lift (type): (A) (B) (C) (J) multiple, multiple, none, piston, rot, submerg, turb, other T Deep Shallow

Power (type): diesel, elec, gas, gasoline, hand, gas, wind; H.P. 150 W Trans. or meter no. _____

Descrip. MP _____ ft above below LSD, Alt. MP _____

Alt. LSD: 126 Accuracy: (source) 3

Water Level: above below MP; Ft. above below LSD 78 Accuracy: 2

Date meas: 669 Yield: 1200 gpm Method determined 4

Drawdown: _____ ft Accuracy: _____ Pumping period: _____ hrs _____

QUALITY OF WATER DATA: Iron _____ Sulfate _____ Chloride _____ Hard. _____

Sp. Conduct 540 K x 10 4 Temp. 22 Date sampled 669

Taste, color, etc. _____

TRANSMITTED FOR ADP PUNCHED and VERIFIED ROLLA COMPUTATION BRANCH

Well No.

D113

DS ≈ 324

