

TRANSMITTED FOR ADP

6/77

Recorded by EHB JAC
Date 7/68 4/26/77

U.S. GEOLOGICAL SURVEY
WATER RESOURCES DIVISION
MISSISSIPPI DISTRICT
WELL RECORD

Well No. D13
E-Log No. 15
County WINSTON

Site ID 331051089065101 R=0* T=A* 2=W*

PUNCHED

GEN. SITE DATA

Data reliab. 3=C* Report. agency 4=USGS* Dist. 6=28* 7=28* Co. 8=159*
Lat. _____ Long. / 9=331051* 10=0890651* Well No. 12=D013*
Location 13=N W N E S 1 2 T 1 5 N R 1 I E * Alt. 16=590.570*
Hyd. Unit (OWDC) 20= Date 21=0910011966*
Well use 23=W* Water Use 24=P* Hole depth 27= Well depth 28=406.*
WL 30=1.84.* Date 31=0210011970* Source 33=S*
Status 273=Y*

WL=195' 7/15/85

OWNER

R=158* T=A* Date 159#0910011966* Owner No. _____
Owner 161=HIGH POINT WA*

FIELD OW

R=192* T=A* Date 193#0310011970* Temp. 196#00010* 197=19.5*
R=192* T=A* Date 193#0310011970* Cond. 196#00095* 197=210.*
R=192* T=A* Date 193# pH 196#00400* 197=

CONSTR.

R=58* T=A* 59#1* Date 60=0910011966* Remarks _____
Drlg. 63=064.* Name _____ Method 65=H* Finish 66=S*

Layne Control

CASING

R=76* T=A* 59#1*
Top csng. 77#0.* Bot. csng. 78=381.* Diam. 79#10.*
R=76* T=A* 59#1*
Top csng 77# Bot. csng. 78= Diam. 79#

OPENINGS

R=82* T=A* 59#1* Top 83#381.* Bottom 84=406.*
Type 85=S* Diam. 87=6.* Size 88=
R=82* T=A* 59#1* Top 83# Bottom 84=
Type 85= Diam. 87= Size 88=

YIELD

R=146.* T=A* 147#1* Q 150=2.25.* Q/S 272=6.6*
134 flows 146 pumped

11/15/82 — WL=217.25

7/15/85 WL=195.00

R=42* T= A * Lift type 43# T* Intake 44= * Power type 45= E*

LIFT

Date 38= 09/00/1966* H.P. 46= 20.*

LOGS

R=198* T= A * Log 199# D* Top 200= 0.* Bot 201= 410.*

R=198* T= A * Log 199# E* Top 200= 4.* Bot 201= 280.*

R=189* T= A * E Log No. 190# 01.5* 191= M I S S D I S T *

ANAL.

R=114* T= A * Year 115# 1970* Type 120= B*

AQUIFERS

R=90* T= A * 256# 1 * Top 91= 38.5.* Bot 92= 40.7.*

Unit ID 93= 124WLCXL* Name of Unit Lower aquifer

R=90* T= A * 256# 1 * Top 91= * Bot 92= *

Unit ID 93= * Name of Unit

HYDRAULICS

R=98* T= A * 99# 1 * Unit tested 100= *

R=105* T= A * 99# 1 * Test No. 106# *

107= * Transmissivity (gal/d)/ft 10300

108= * Hydraul. cond. (gal/d)/ft² 370

110= * Storage coeff. Boundaries

240' pump setting