

GW12670

PUNCH
APR 18 1975

FORM 9-1642
(1-68)

Well No. 69

WELL SCHEDULE

U. S. DEPT. OF THE INTERIOR

GEOLOGICAL SURVEY

WATER RESOURCES DIVISION

MASTER CARD

Record by G. J. Dalsin Source of data Mr. Hall Date 2-25-1971 Map Yazoo City
(E. J. Harvey 3-23-65)

State 28 County (or town) Yazoo 82

Latitude: 32 50 45 N Longitude: 09 02 30 Sequential number: 1

Local well number: G 0 0 9 D B 3 2 1 2 N O 2 W Other well number: #163

Local use: 064 Owner or name: NW/SW/SW/NE

Owner or name: YAZOO CITY Address: Yazoo City, Miss.

Ownership: County, Fed Gov't, (M) City, Corp or Co, Private, State Agency, Water Dist (M)

Use of water: Air cond, Bottling, Comm, Dewater, Power, Fire, Dom, Irr, Med, Ind, (P) P S Rec, Stock, Instic, Unused, Repressure, Recharge, Desal-P S, Desal-other, Other IN PE

Use of well: Anode, Drain, Seismic, Heat Res, Obs, Oil-gas, Recharge, Test, Unused, (W) Withdraw, Waste, Destroyed. W

DATA AVAILABLE: Well data Freq W/L meas: Field aquifer char:

Hyd. lab. data: MRVA

Qual. water data; type: U.S.G.S. 1-3-56

Freq. sampling: Pumpage inventory: yes no; period:

Aperture cards: yes

Log data:

WELL-DESCRIPTION CARD

SAME AS ON MASTER CARD Depth well: 192 Meas. accuracy 6

Depth cased: 132 Casing type: 1 1/8 Diam. 1 7/8 in

Finish: porous concrete, gravel w. screen, gravel w. horiz. gallery, open perf., (S) screen sd. pt., shored, other S

Method: (A) air bored, cable, dug, hyd jetted, percussive, (R) reverse trenching, driven, drive wash, other P

Date Drilled: 957 Pump intake setting: 94 ft

Driller: Layne Central name Watson address

Lift (type): (A) air, bucket, cent, jet, multiple, multiple, none, piston, rot, submerg, (T) turb other T Deep 40 Shallow 39

Power (type): diesel, (elec) gas, gasoline, hand, gas, wind; H.P. 100 Trans. or meter no. 41

Descrp. MP 94 above ft below LSD, Alt. MP

Alt. LSD: 100 ± ft. Accuracy: Topo

Water Level: 29.5 ft above MP; 30 ft below LSD Accuracy: D

Date meas: 957 Yield: 1200 gpm Method determined: 1500

Drawdown: 62 ft Accuracy: 63 Pumping period: 66 hrs

QUALITY OF WATER DATA: Iron 69 Sulfate 70 Chloride 71 Hard. 72

Sp. Conduct 73 K x 10 74 Temp. 75 Date sampled 76 77 79

Taste, color, etc.

Well No.

69

